


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER AS 25T 2727805 (S/N 1190)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

		Feb2017 Oct2	017 Jul2019 Dec2020 Aug2	022 Nov2022 Feb2023 May2023 Sep20	023 Apr2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA017173	KCPA003545	KCPA001992
Sample Date		Client Info		16 Apr 2024	08 Sep 2023	26 May 2023
Machine Age	hrs	Client Info		41493	39953	39238
Oil Age	hrs	Client Info		2737	0	0
Oil Changed		Client Info		Changed	N/A	N/A
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	0
Aluminum	ppm	ASTM D5185m	>10	3	3	0
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m		7	2	1
Tin	ppm	ASTM D5185m	>10	, <1	0	0
Vanadium	ppm	ASTM D5185m	7.0	<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES	ррш	method	limit/base	current	history1	history2
			IIIIIIVDase			
Boron	ppm	ASTM D5185m	00	0	0	0
Barium	ppm	ASTM D5185m	90	<1	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	90	12	41	75
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		0	1	1
Zinc	ppm	ASTM D5185m		26	21	17
Sulfur	ppm	ASTM D5185m		19580	21685	22791
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		4	16	19
Potassium	ppm	ASTM D5185m	>20	2	2	3
Water	%	ASTM D6304	>0.05	0.009	0.018	0.020
ppm Water	ppm	ASTM D6304	>500	93	189.8	208.0
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		7350	2064	11106
Particles >6µm		ASTM D7647	>1300	2506	535	<u>^</u> 2668
Particles >14µm		ASTM D7647	>80	<u>^</u> 261	57	<u> </u>
Particles >21µm		ASTM D7647	>20	<u>^</u> 87	21	20
Particles >38µm		ASTM D7647	>4	8	2	0
Particles >71µm		ASTM D7647	>3	1	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/19/15	18/16/13	<u>^</u> 21/19/14
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.30	0.31	0.36



OIL ANALYSIS REPORT







Laboratory

Sample No. Lab Number

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KCPA017173 : 06156928

Unique Number: 10992351

Test Package : IND 2 (Additional Tests: KF, PrtCount)

Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Received : 22 Apr 2024 **Tested** : 23 Apr 2024 Diagnosed : 24 Apr 2024 - Angela Borella

Contact: SERVICE MANAGER juand@lumberhardware.com

ALLEN & ALLEN COMPANY

202 CULEBRA RD

SAN ANTONIO, TX

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

US 78201

T:

F: