


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER 8146734 (S/N 2091)

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

			May2023	Apr2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA016587	KCPA001866	
Sample Date		Client Info		18 Apr 2024	15 May 2023	
Machine Age	hrs	Client Info		10398	3791	
Oil Age	hrs	Client Info		3000	0	
Oil Changed	1110	Client Info		Changed	N/A	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
						HISTOLYZ
Iron Chromium	ppm	ASTM D5185m ASTM D5185m	>50 >10	0 <1	<1	
Nickel	ppm					
	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m		<1	0	
Silver	ppm	ASTM D5185m	>2	<1	0	
Aluminum	ppm	ASTM D5185m	>10	3	0	
Lead	ppm	ASTM D5185m	>10	<1	0	
Copper	ppm	ASTM D5185m	>50	11	6	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	0	<1	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m	100	40	59	
Calcium	ppm	ASTM D5185m	0	0	0	
Phosphorus	ppm	ASTM D5185m	0	0	1	
Zinc	ppm	ASTM D5185m	0	0	0	
Sulfur	ppm	ASTM D5185m	23500	21257	21746	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	0	
Sodium	ppm	ASTM D5185m		13	14	
Potassium	ppm	ASTM D5185m	>20	4	2	
Water	%	ASTM D6304	>0.05	0.010	0.021	
ppm Water	ppm	ASTM D6304	>500	106	219.8	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		18481	8726	
Particles >6µm		ASTM D7647	>1300	5933	<u>^</u> 2582	
Particles >14µm		ASTM D7647	>80	297	59	
Particles >21µm		ASTM D7647	>20	<u> </u>	9	
Particles >38µm		ASTM D7647	>4	2	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 21/20/15	<u>△</u> 20/19/13	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.39	0.33	
` '	0					



OIL ANALYSIS REPORT





Certificate 12367

Laboratory Sample No.

Lab Number : 06156954

: KCPA016587 Unique Number: 10992377

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 22 Apr 2024 Tested : 23 Apr 2024

Diagnosed : 24 Apr 2024 - Angela Borella

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

MEDLINE NDUSTRIES LP

5511 W TEN RD MEBANE, NC US 27302 Contact: A. KOBAE

akobae@medline.com T:

F: