KAESER COMPRESSORS
Built for a lifetime.

OIL ANALYSIS REPORT

Sample Rating Trend



ISO

Machine Id
KAESER SM 10 3041647 (S/N 1163)
Component
Compressor
Fluid
KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation
We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is a high amount of particulates present in the oil.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**KCPA017189**	KCPA001539	KCP35330
Sample Date		Client Info		**11 Apr 2024**	23 Mar 2023	01 Mar 2022
Machine Age	hrs	Client Info		**40152**	32429	34795
Oil Age	hrs	Client Info		**2723**	0	3000
Oil Changed		Client Info		**N/A**	N/A	Changed
Sample Status				**ABNORMAL**	NORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	**<1**	0	6
Chromium	ppm	ASTM D5185m	>10	**<1**	0	0
Nickel	ppm	ASTM D5185m	>3	**<1**	0	0
Titanium	ppm	ASTM D5185m	>3	**<1**	<1	0
Silver	ppm	ASTM D5185m	>2	**<1**	0	<1
Aluminum	ppm	ASTM D5185m	>10	**3**	<1	2
Lead	ppm	ASTM D5185m	>10	**<1**	0	0
Copper	ppm	ASTM D5185m	>50	**6**	6	9
Tin	ppm	ASTM D5185m	>10	**<1**	0	0
Antimony	ppm	ASTM D5185m		**---**	---	---
Vanadium	ppm	ASTM D5185m		**<1**	<1	0
Cadmium	ppm	ASTM D5185m		**<1**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		**0**	0	2
Barium	ppm	ASTM D5185m	90	**2**	0	0
Molybdenum	ppm	ASTM D5185m		**<1**	0	0
Manganese	ppm	ASTM D5185m		**<1**	0	<1
Magnesium	ppm	ASTM D5185m	90	**63**	42	48
Calcium	ppm	ASTM D5185m	2	**0**	<1	0
Phosphorus	ppm	ASTM D5185m		**0**	0	1
Zinc	ppm	ASTM D5185m		**4**	0	15
Sulfur	ppm	ASTM D5185m		**19818**	22196	16472

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	**23**	17	20
Sodium	ppm	ASTM D5185m		**20**	18	9
Potassium	ppm	ASTM D5185m	>20	**5**	<1	2
Water	%	ASTM D6304	>0.05	**0.016**	0.026	▲ 0.491
ppm Water	ppm	ASTM D6304	>500	**163**	265.5	▲ 4910

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		**5219**	683	---
Particles >6µm		ASTM D7647	>1300	▲ **1973**	220	---
Particles >14µm		ASTM D7647	>80	▲ **271**	29	---
Particles >21µm		ASTM D7647	>20	▲ **94**	8	---
Particles >38µm		ASTM D7647	>4	▲ **6**	0	---
Particles >71µm		ASTM D7647	>3	**1**	0	---
Oil Cleanliness		ISO 4406 (c)	>--/17/13	▲ **20/18/15**	17/15/12	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	**0.34**	0.27	0.41

KAESER COMPRESSORS
Built for a lifetime.

OIL ANALYSIS REPORT

Particle Trend



Water (KF)



Acid Number



Water (KF)



Viscosity @ 40°C



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	▲ MODER
Debris	scalar	*Visual	NONE	**NONE**	LIGHT	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	● HAZY
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	**NEG**	NEG	▲ 0.2%
Free Water	scalar	*Visual		**NEG**	NEG	▲ 1.0

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	**44.4**	43.5	43.9

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS

Ferrous Alloys



Non-ferrous Metals



Viscosity @ 40°C



Particle Count



Acid Number



ANAB ACCREDITED ISO/IEC 17025 TESTING LABORATORY
Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA017189
Lab Number : 06156956
Unique Number : 10992379
Test Package : IND 2 (Additional Tests: KF, PrtCount)

Received : 22 Apr 2024
Tested : 23 Apr 2024
Diagnosed : 25 Apr 2024 - Jonathan Hester

TIDE DRY CLEANERS
13420 ROE AVE
LEAWOOD, KS
US 66209
Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: