

OIL ANALYSIS REPORT

Area ULTRA COOLANT Machine Id INGERSOLL RAND CBV216434 - TCC PORTSMOUTH

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Sample Rating Trend



NORMAL


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06157065		
Sample Date		Client Info		10 Apr 2024		
Machine Age	hrs	Client Info		186		
Oil Age	hrs	Client Info		186		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m		2		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m	556	339		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		2		
Calcium	ppm	ASTM D5185m	242	7		
Phosphorus	ppm	ASTM D5185m	0	3		
Zinc	ppm	ASTM D5185m	0	31		
Sulfur	ppm	ASTM D5185m	306	273		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3		
Sodium	ppm	ASTM D5185m		26		
Potassium	ppm	ASTM D5185m	>20	3		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.2	0.31		



46 44 Apr10/24

ŝ,

OIL ANALYSIS REPORT



	VISUAL		method	limit/base	current	history1	history2
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
Apr10/24	Appearance	scalar	*Visual	NORML	NORML		
Ap	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.1	NEG		
	Free Water	scalar	*Visual		NEG		
	FLUID PROPERT	TIES	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445	52	51.0		
	SAMPLE IMAGES	S	method	limit/base	current	history1	history2
Apr10/24 +	Color				a.	no image	no image
	Bottom					no image	no image
	wdd 4 2 0 4 7 5 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7			April0/24			
	Non-ferrous Metal	s					
	Apr10/24			Apr10/24			
	< Viscosity @ 40°C			A	Acid Number		
	60 Abnormal			€0.4			
	ç 55			Đy 0.3	0		
	(J) 55 Base 35 50			(0,0.4 (0,0.4) Bull Jack (0,0.4) Bull Jack (0,0.	0 - Base		
				P 0.1	0		
	45 Abnormal			0.0	0		
	Apr10/24			Apr10/24	Apr10/24		ACOLON
	Apr			Apr	Api		
Laboratory Sample No. Lab Number Unique Number Test Package	: 10992488	TATE ENGINEERIN 8131 VIRGINIA PINE C RICHMOND, V US 2323 Contact: JOE MYRIC JOE.MYRICK@TATE.COI T: (804)339-000					

Contact/Location: JOE MYRICK - UCTATRIC

Page 2 of 2