




OIL ANALYSIS REPORT

Sample Rating Trend



GLYCOL

Machine Id

E-2 (S/N 1144675)

Component

Biogas Engine

Fluid

MAHLER Q8 Mahler G8 SAE 40 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you check for the source of the coolant leak. Check for low coolant level. Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

Sodium and/or potassium levels are high.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0914283	WC0914276	WC0914324
Sample Date	Client Info		17 Apr 2024	08 Apr 2024	01 Apr 2024
Machine Age	hrs	Client Info	12464	12404	12240
Oil Age	hrs	Client Info	34	5668	5504
Oil Changed	Client Info		Changed	Not Changd	Not Changd
Sample Status			ABNORMAL	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Water	WC Method	>0.1	NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>45	8	7
Chromium	ppm	ASTM D5185m	>2	<1	1
Nickel	ppm	ASTM D5185m	>2	0	1
Titanium	ppm	ASTM D5185m		0	<1
Silver	ppm	ASTM D5185m	>5	0	0
Aluminum	ppm	ASTM D5185m	>10	4	6
Lead	ppm	ASTM D5185m	>5	3	5
Copper	ppm	ASTM D5185m	>14	<1	2
Tin	ppm	ASTM D5185m	>13	4	6
Vanadium	ppm	ASTM D5185m		0	<1
Cadmium	ppm	ASTM D5185m		<1	<1

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		3	0
Barium	ppm	ASTM D5185m		2	0
Molybdenum	ppm	ASTM D5185m		2	2
Manganese	ppm	ASTM D5185m		<1	1
Magnesium	ppm	ASTM D5185m		10	10
Calcium	ppm	ASTM D5185m		2421	2725
Phosphorus	ppm	ASTM D5185m		430	503
Zinc	ppm	ASTM D5185m		517	567
Sulfur	ppm	ASTM D5185m		2902	3282

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>200	27	46
Sodium	ppm	ASTM D5185m		▲ 275	2
Potassium	ppm	ASTM D5185m	>20	▲ 41	3

INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0	0
Nitration	Abs/cm	*ASTM D7624	>20	9.0	10.0
Sulfation	Abs/.1mm	*ASTM D7415	>30	19.0	23.4


FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	12.6	19.8
Acid Number (AN)	mg KOH/g	ASTM D8045		0.92	2.09
Base Number (BN)	mg KOH/g	ASTM D2896	8.0	7.40	5.32




OIL ANALYSIS REPORT


▲ Glycol Contamination




FT-IR (Direct Trend)




Acid Number



Base Number



Viscosity @ 100°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.2	14.0	14.5

GRAPHS


Iron (ppm)




Lead (ppm)




Aluminum (ppm)




Chromium (ppm)




Copper (ppm)




Silicon (ppm)



Viscosity @ 100°C



Base Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : WC0914283

Lab Number : 06157089

Unique Number : 10992512

Test Package : MOB 2

Received : 22 Apr 2024

Tested : 23 Apr 2024

Diagnosed : 25 Apr 2024 - Jonathan Hester

OAK GROVE GA

967 CARL-BETHLEHEM RD

WINDER, GA

US 30680

Contact: ZACK GRAVES

zack.graves@cubedistrictenergy.com

T: (470)596-8000

F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)