

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Area WP29 Machine Id MVR112-5 effect Hydraulic System

MOBIL DTE 25 (93 GAL)

Recommendation

Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.




SAMPLE INFORI	MATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		WC0859488	WC0875268	WC0875265	
Sample Date		Client Info		15 Apr 2024	01 Apr 2024	25 Mar 2024	
Machine Age	hrs	Client Info		0	0	0	
Dil Age	hrs	Client Info		0	0	0	
Dil Changed		Client Info		N/A	N/A	N/A	
Sample Status				NORMAL	NORMAL	NORMAL	
CONTAMINATIO	N	method	limit/base	current	history1	history2	
Water		WC Method	>0.05	NEG	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2	
ron	ppm	ASTM D5185m	>20	1	2	<1	
Chromium	ppm	ASTM D5185m	>20	<1	<1	0	
Nickel	ppm	ASTM D5185m	>20	<1	<1	<1	
Titanium	ppm	ASTM D5185m		<1	<1	0	
Silver	ppm	ASTM D5185m		0	0	0	
Aluminum	ppm	ASTM D5185m	>20	2	2	0	
_ead	ppm	ASTM D5185m	>20	0	<1	0	
Copper	ppm	ASTM D5185m		1	1	<1	
Tin	ppm	ASTM D5185m	>20	- <1	1	0	
Vanadium	ppm	ASTM D5185m		<1	<1	<1	
Cadmium	ppm	ASTM D5185m		<1	<1	0	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0	0	0	
Barium	ppm	ASTM D5185m		0	0	0	
Volybdenum	ppm	ASTM D5185m		<1	<1	0	
Vanganese	ppm	ASTM D5185m		0	<1	0	
Vagnesium	ppm	ASTM D5185m		2	3	0	
Calcium	ppm	ASTM D5185m		81	93	86	
		ASTM D5185m		422	428	473	
Phosphorus	ppm	ASTM D5185m		638	626	623	
Zinc	ppm						
Sulfur	ppm	ASTM D5185m		2511	2405	2863	
CONTAMINANTS		method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m		2	2	<1	
Sodium	ppm	ASTM D5185m		2	<1	3	
Potassium	ppm	ASTM D5185m	>20	2	1	2	
FLUID CLEANLIN	VESS	method	limit/base	current	history1	history2	
Particles >4µm		ASTM D7647	>5000	906	246	189	
Particles >6µm		ASTM D7647	>1300	231	56	40	
Particles >14µm		ASTM D7647	>160	18	5	5	
Particles >21µm		ASTM D7647	>40	3	2	2	
Particles >38µm		ASTM D7647	>10	0	0	0	
Particles >71µm		ASTM D7647	>3	0	0	0	
Oil Cleanliness		ISO 4406 (c)	>19/17/14	17/15/11	15/13/10	15/12/10	
FLUID DEGRAD	ATION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045		0.97	0.842	1.11	
5:52) Bev: 1 Submitted Bv: VINCENT MCINTI							


Report Id: LEPNEW [WUSCAR] 06157644 (Generated: 04/24/2024 12:35:52) Rev: 1


Submitted By: VINCENT MCINTIRE




OIL ANALYSIS REPORT










VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	44.2	47.8	47.7	47.6
SAMPLE IMAGES	3	method	limit/base	current	history1	history2
Color						



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 LEPRINO FOODS-ROSWELL Sample No. : WC0859488 Received : 23 Apr 2024 5600 OMAHA RD Lab Number : 06157644 Tested : 24 Apr 2024 ROSWELL, NM Unique Number : 10993067 Diagnosed : 24 Apr 2024 - Wes Davis US 88203 Test Package : IND 2 Contact: VINCENT MCINTIRE Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369. vmcintire@leprinofoods.com

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (505)347-5728

Report Id: LEPNEW [WUSCAR] 06157644 (Generated: 04/24/2024 12:35:52) Rev: 1

Submitted By: VINCENT MCINTIRE

Page 2 of 2

T: