

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

60-PC-24 (S/N 429) Gomponent Hydraulic System Fluid MILITARY MIL-PRF-87257 (--- LTR)

DIAGNOSIS

A Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

Elemental level of silicon (Si) above normal. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0887180		
Sample Date		Client Info		16 Apr 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
	222		>20			
Iron	ppm	ASTM D5185m		0		
Chromium	ppm	ASTM D5185m	>20	<1		
Nickel	ppm	ASTM D5185m	>20	<1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m		2		
Lead	ppm	ASTM D5185m	>20	0		
Copper	ppm	ASTM D5185m	>20	<1		
Tin	ppm	ASTM D5185m	>20	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		<1		
Molybdenum	ppm	ASTM D5185m		<1		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		<1		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		509		
Zinc	ppm	ASTM D5185m		2		
Sulfur	ppm	ASTM D5185m		9		
CONTAMINANTS		method	limit/base	current	history1	history2
					TIIStory I	
Silicon	ppm	ASTM D5185m	>15	1 9		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	1		
Water	%	ASTM D6304	>0.05	NEG		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	939		
Particles >6µm		ASTM D7647	>1300	87		
Particles >14µm		ASTM D7647	>160	6		
Particles >21µm		ASTM D7647	>40	3		
Particles >38µm		ASTM D7647	>10	0		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>19/17/14	17/14/10		
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.42		



60

50

40

۲<u>ط</u> 30

20

10

0 Apr16/24

6 Ê 5

₩ 3k

Ok

0.50

(B/HO) Ê0.30

Pio 0.1

0.00

cSt (40°C)

5

Base

Anr16/74

6


Ê 5


E 31

2

0

OIL ANALYSIS REPORT





history1

history

history1

no image

no image

current

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

current

current

60-

NEG

NEG

8.6

history2

history

history2

no imade

no imade



Sample No. : WC0887180 Received : 23 Apr 2024 25200 W RYE CANYON RD Lab Number Tested : 25 Apr 2024 SANTA CLARITA, CA : 06157650 Unique Number : 10993073 Diagnosed : 25 Apr 2024 - Jonathan Hester Test Package : PLANT Contact: REYNARD GOLDMAN Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369. reynard.goldman@woodward.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: (661)702-5991 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: WOOSANCA [WUSCAR] 06157650 (Generated: 04/25/2024 20:07:07) Rev: 1

Contact/Location: REYNARD GOLDMAN - WOOSANCA

E:

WOODWARD

US 91355