



OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
650916 - HTLL
 Component
Power Steering Fluid
 Fluid
FUCHS TITAN CHF 11S (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the power steering fluid.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the power steering fluid is suitable for further service.

| SAMPLE INFORMATION | | method | limit/base | current | history1 | history2 |
|--------------------|-------------|-------------|------------|--------------------|----------|----------|
| Sample Number | Client Info | | | PH0002967 | --- | --- |
| Sample Date | Client Info | | | 12 Apr 2024 | --- | --- |
| Machine Age | hrs | Client Info | | 0 | --- | --- |
| Oil Age | hrs | Client Info | | 0 | --- | --- |
| Oil Changed | Client Info | | | N/A | --- | --- |
| Sample Status | | | | ABNORMAL | --- | --- |

| CONTAMINATION | | method | limit/base | current | history1 | history2 |
|---------------|-----------|--------|------------|------------|----------|----------|
| Water | WC Method | | | NEG | --- | --- |


| WEAR METALS | | method | limit/base | current | history1 | history2 |
|-------------|-----|-------------|------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185m | | 1 | --- | --- |
| Chromium | ppm | ASTM D5185m | | <1 | --- | --- |
| Nickel | ppm | ASTM D5185m | | 1 | --- | --- |
| Titanium | ppm | ASTM D5185m | | <1 | --- | --- |
| Silver | ppm | ASTM D5185m | | 0 | --- | --- |
| Aluminum | ppm | ASTM D5185m | | 3 | --- | --- |
| Lead | ppm | ASTM D5185m | | 0 | --- | --- |
| Copper | ppm | ASTM D5185m | | <1 | --- | --- |
| Tin | ppm | ASTM D5185m | | <1 | --- | --- |
| Vanadium | ppm | ASTM D5185m | | <1 | --- | --- |
| Cadmium | ppm | ASTM D5185m | | <1 | --- | --- |

| ADDITIVES | | method | limit/base | current | history1 | history2 |
|------------|-----|-------------|------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m | | 170 | --- | --- |
| Barium | ppm | ASTM D5185m | | 0 | --- | --- |
| Molybdenum | ppm | ASTM D5185m | | <1 | --- | --- |
| Manganese | ppm | ASTM D5185m | | <1 | --- | --- |
| Magnesium | ppm | ASTM D5185m | | 4 | --- | --- |
| Calcium | ppm | ASTM D5185m | | 24 | --- | --- |
| Phosphorus | ppm | ASTM D5185m | | 413 | --- | --- |
| Zinc | ppm | ASTM D5185m | | 6 | --- | --- |
| Sulfur | ppm | ASTM D5185m | | 827 | --- | --- |

| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
|--------------|-----|-------------|------------|----------|----------|----------|
| Silicon | ppm | ASTM D5185m | | 7 | --- | --- |
| Sodium | ppm | ASTM D5185m | | 2 | --- | --- |
| Potassium | ppm | ASTM D5185m | >20 | 1 | --- | --- |





| FLUID CLEANLINESS | | method | limit/base | current | history1 | history2 |
|-------------------|--------------|----------|------------|-------------------|----------|----------|
| Particles >4µm | ASTM D7647 | >160 | | ▲ 83607 | --- | --- |
| Particles >6µm | ASTM D7647 | >40 | | ▲ 14561 | --- | --- |
| Particles >14µm | ASTM D7647 | >4 | | ▲ 512 | --- | --- |
| Particles >21µm | ASTM D7647 | >3 | | ▲ 96 | --- | --- |
| Particles >38µm | ASTM D7647 | >3 | | 2 | --- | --- |
| Particles >71µm | ASTM D7647 | >3 | | 0 | --- | --- |
| Oil Cleanliness | ISO 4406 (c) | >14/12/9 | | ▲ 24/21/16 | --- | --- |

| FLUID DEGRADATION | | method | limit/base | current | history1 | history2 |
|-------------------|----------|------------|------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | | 1.75 | --- | --- |





OIL ANALYSIS REPORT



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PH0002967 **Received** : 23 Apr 2024
Lab Number : 06157680 **Tested** : 25 Apr 2024
Unique Number : 10993103 **Diagnosed** : 25 Apr 2024 - Jonathan Hester
Test Package : PLANT (Additional Tests: PrtFilter)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

PARKER HANNIFIN
 5520 HWY 169 N
 NEW HOPE, MN
 US 55428

Contact: MATT DALEO
 matthew.daleo@parker.com

T:
F:

| VISUAL | method | limit/base | current | history1 | history2 | |
|------------------|--------|------------|---------|----------|----------|-----|
| White Metal | scalar | *Visual | NONE | NONE | --- | --- |
| Yellow Metal | scalar | *Visual | NONE | NONE | --- | --- |
| Precipitate | scalar | *Visual | NONE | NONE | --- | --- |
| Silt | scalar | *Visual | NONE | NONE | --- | --- |
| Debris | scalar | *Visual | NONE | NONE | --- | --- |
| Sand/Dirt | scalar | *Visual | NONE | NONE | --- | --- |
| Appearance | scalar | *Visual | NORML | NORML | --- | --- |
| Odor | scalar | *Visual | NORML | NORML | --- | --- |
| Emulsified Water | scalar | *Visual | NEG | --- | --- | |
| Free Water | scalar | *Visual | NEG | --- | --- | |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 | |
|------------------|--------|------------|---------|----------|----------|-----|
| Visc @ 40°C | cSt | ASTM D445 | 18.7 | 19.2 | --- | --- |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|

| | | | |
|-----------|--|----------|----------|
| Color | | no image | no image |
| Bottom | | no image | no image |
| PrtFilter | | no image | no image |

GRAPHS

