


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER AS 36 3613332

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Feb 2021	Dec2021 Jun2022	Oct2022 Jan2023 Oct2023	Apr2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC06157715	KC123145	KC108114
Sample Date		Client Info		15 Apr 2024	16 Oct 2023	17 Jan 2023
Machine Age	hrs	Client Info		39761	39715	39616
Oil Age	hrs	Client Info		0	0	96
Oil Changed		Client Info		N/A	N/A	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1	0	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	<1	2	1
Tin	ppm	ASTM D5185m	>10	<1	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	34	30	75
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	90	82	36	80
Calcium	ppm	ASTM D5185m	2	0	<1	2
Phosphorus	ppm	ASTM D5185m		0	5	3
Zinc	ppm	ASTM D5185m		4	8	4
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	1	2
Sodium	ppm	ASTM D5185m		10	4	3
Potassium	ppm	ASTM D5185m	>20	2	2	<1
Water	%	ASTM D6304	>0.05	0.011	<u></u>	0.011
ppm Water	ppm	ASTM D6304	>500	118	<u>\$\text{\tint{\text{\tin}\text{\tex{\tex</u>	117.7
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		28043	1038	60611
Particles >6µm		ASTM D7647		<u>▲</u> 3287	165	<u>▲</u> 15162
Particles >14μm		ASTM D7647	>80	76	15	△ 972
Particles >21µm		ASTM D7647		16	4	<u>^</u> 263
Particles >38µm		ASTM D7647	>4	1	0	<u>^</u> 9
Particles >71μm		ASTM D7647		0	0	1
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>22/19/13</u>	17/15/11	<u>\$\rightarrow\$ 23/21/17</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.47	0.35	0.31



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number

Test Package : IND 2

: KC06157715 : 06157715 Unique Number : 10993138

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 23 Apr 2024 **Tested** : 24 Apr 2024

Jan 17/23

Diagnosed : 25 Apr 2024 - Don Baldridge

NORMAN NOBLE 5340 AVION PKWY HIGHLAND HEIGHTS, OH US 44143

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: