


## **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# BUSCH CONVERSION P-06 CV-12 VACUUM (S/N U091301825)

Component **Pump** 

**USPI VAC 100 (--- GAL)** 

DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		ar2017 Dec20	17 Nov2018 Sep2019	Nov2020 Dec2021 Nov2022 Ju	2023 Apr202	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USPM36783	USPM30664	USPM31074
Sample Date		Client Info		22 Apr 2024	17 Jan 2024	18 Oct 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>90	<1	0	0
Chromium	ppm	ASTM D5185m	>5	<1	0	0
Nickel	ppm	ASTM D5185m	>5	<1	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>7	2	0	0
Lead	ppm	ASTM D5185m	>12	0	<1	0
Copper	ppm	ASTM D5185m	>30	<1	0	0
Tin	ppm	ASTM D5185m	>9	<1	<1	<1
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	<1	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	0	<1	1	0
Calcium	ppm	ASTM D5185m	0	0	1	0
Phosphorus	ppm	ASTM D5185m	1800	808	956	926
Zinc	ppm	ASTM D5185m	0	0	0	0
Sulfur	ppm	ASTM D5185m	0	0	16	7
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	13	12	2
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	1	0	<1
Water	%	ASTM D6304	>.1	0.038	0.029	0.099
ppm Water	ppm	ASTM D6304	>1000	380	297	991.2
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	740	2146	3851
Particles >6µm		ASTM D7647	>1300	181	576	659
Particles >14μm		ASTM D7647	>160	14	53	31
Particles >21µm		ASTM D7647	>40	5	12	11
Particles >38μm		ASTM D7647	>10	1	1	2
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>19/17/14	17/15/11	18/16/13	19/17/12
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.05	0.044	0.23	0.094



## **OIL ANALYSIS REPORT**







Certificate 12367

Laboratory Sample No. Lab Number

: USPM36783 : 06157720 Unique Number : 10993143 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 23 Apr 2024

**Tested** : 24 Apr 2024 Diagnosed

: 25 Apr 2024 - Jonathan Hester

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: SMITAR [WUSCAR] 06157720 (Generated: 04/25/2024 20:02:03) Rev: 1

Contact/Location: SERVICE MANAGER - SMITAR

**SMITHFIELD FOOD - TARHEEL** 

Contact: SERVICE MANAGER

15855 HWY. 87 WEST

TARHEEL, NC

US 28392

T:

F: