


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

**GEA RC-1/HS-1** 

Component Refrigeration Compressor

# **CAMCO 717 HT (85 GAL)**

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

The water content is negligible. There is no indication of any contamination in the oil.


### **Fluid Condition**


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0918563	WC0908557	WC0878464
Sample Date		Client Info		15 Apr 2024	02 Apr 2024	29 Dec 2023
Machine Age	hrs	Client Info		74303	73988	71984
Oil Age	hrs	Client Info		0	73988	71984
Oil Changed		Client Info		N/A	N/A	Not Changd
Sample Status				NORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	13	<u> </u>	<u>^</u> 28
Chromium	ppm	ASTM D5185m	>2	<1	0	<1
Nickel	ppm	ASTM D5185m		0	0	<1
Titanium	ppm	ASTM D5185m		0	0	<1
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	<1	0	0
Lead	ppm	ASTM D5185m	>2	0	0	<1
Copper	ppm	ASTM D5185m	>8	0	0	<1
Tin	ppm	ASTM D5185m	>4	1	<1	2
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	<1
ADDITIVES		method	limit/base	current	history1	history2
ADDITIVES Boron	ppm	method ASTM D5185m	limit/base	current <b>0</b>	history1	history2
	ppm		limit/base			
Boron		ASTM D5185m	limit/base	0	0	0
Boron Barium	ppm	ASTM D5185m ASTM D5185m	limit/base	0 0	0	0
Boron Barium Molybdenum	ppm	ASTM D5185m ASTM D5185m ASTM D5185m	limit/base	0 0 0 <1 1	0 0 0	0 8 <1 <1 <1
Boron Barium Molybdenum Manganese	ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	limit/base	0 0 0 <1	0 0 0	0 8 <1 <1 <1 <1 2
Boron Barium Molybdenum Manganese Magnesium	ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	limit/base	0 0 0 <1 1 0	0 0 0 0 0 0	0 8 <1 <1 <1 <1 2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc	ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	limit/base	0 0 0 <1 1 0 0	0 0 0 0 0 0	0 8 <1 <1 <1 2 7
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus	ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	limit/base	0 0 0 <1 1 0	0 0 0 0 0 0	0 8 <1 <1 <1 <1 2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc	ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	limit/base	0 0 0 <1 1 0 0	0 0 0 0 0 0	0 8 <1 <1 <1 2 7
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur	ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m		0 0 0 <1 1 0 0	0 0 0 0 0 0 0	0 8 <1 <1 <1 2 7 0
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS	ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	limit/base	0 0 0 <1 1 0 0 0 0	0 0 0 0 0 0 0 0 0 0	0 8 <1 <1 <1 2 7 0 0
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS	ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m	limit/base	0 0 0 <1 1 0 0 0 0 current	0 0 0 0 0 0 0 0 0 0 0 history1	0 8 <1 <1 <1 2 7 0 0 history2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS Silicon Sodium	ppm ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m	limit/base	0 0 0 <1 1 1 0 0 0 0 0 current 2	0 0 0 0 0 0 0 0 0 0 0 history1	0 8 <1 <1 <1 <1 2 7 0 0 history2 4
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS Silicon Sodium Potassium	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m	limit/base >15 >20	0 0 0 <1 1 1 0 0 0 0 0 current 2 <1 2	0 0 0 0 0 0 0 0 0 0 history1 2	0 8 <1 <1 <1 <1 2 7 0 0 0 history2 4 0 <1
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS Silicon Sodium Potassium Water	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m	limit/base >15 >20 >0.01	0 0 0 0 <1 1 0 0 0 0 0 current 2 <1 2 0.001	0 0 0 0 0 0 0 0 0 history1 2 0 0	0 8 <1 <1 <1 2 7 0 0 history2 4 0 <1



## **OIL ANALYSIS REPORT**








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.01	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES		method				history2
Visc @ 40°C	cSt	ASTM D445	69	65.0	65.2	65.3


SAMPLE IMAGES	method		history2


Color







### **GRAPHS**













Certificate 12367

Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Lab Number : 06157752

: WC0918563 Unique Number : 10993175

Received : 23 Apr 2024 **Tested** : 24 Apr 2024

Diagnosed : 25 Apr 2024 - Jonathan Hester **FROZEN ASSETS** 

2635 S WESTERN AVE CHICAGO, IL US 60608

Contact: Service Manager

Test Package : IND 2 To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: