


OIL ANALYSIS REPORT

NOT GIVEN [03-100154] INGERSOL RAND CK0291U98092 - LINE MANUFACTURING

Component





Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06157797		
Sample Date		Client Info		18 Apr 2024		
Machine Age	hrs	Client Info		59251		
Oil Age	hrs	Client Info		8000		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		<1		
Aluminum	ppm	ASTM D5185m	>25	<1		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		719		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		13		
Calcium	ppm	ASTM D5185m		18		
Phosphorus	ppm	ASTM D5185m		81		
Zinc	ppm	ASTM D5185m		17		
Sulfur	ppm	ASTM D5185m		297		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2		
Sodium	ppm	ASTM D5185m		27		
Potassium	ppm	ASTM D5185m	>20	4		
FLUID DEGRADA	NOITA	method	limit/base	current	history1	history2


0.16

Acid Number (AN)

mg KOH/g ASTM D8045




OIL ANALYSIS REPORT





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.1	NEG		
Free Water	scalar	*Visual		NEG		
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		50.0		
SAMPLE IMAGES	6	method	limit/base	current	history1	history2
Color					no image	no image


GRAPHS

Bottom









no image

no image





Report Id: UCAIRCAR [WUSCAR] 06157797 (Generated: 04/25/2024 20:08:01) Rev: 1

Laboratory Sample No. Lab Number : 06157797

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : UCH06157797

Unique Number : 10993220

Received : 23 Apr 2024 **Tested** Diagnosed

: 24 Apr 2024 : 25 Apr 2024 - Don Baldridge

AIRMATIC COMPRESSOR SYSTEMS 700 WASHINGTON AVE

CARLSTADT, NJ US 07072 Contact: ELVIN DIAZ

F: (201)342-6241

Test Package : IND 2 Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

ediaz@airmaticcompressor.com;canastasio@wearcheckusa.com T: (800)864-7621

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: ELVIN DIAZ - UCAIRCAR