




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area

Kenova

Machine Id

[Kenova] Oil - Starboard Main Engine

Component

Port Main Engine

Fluid

MOBIL 15W40 (150 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. (Customer Sample Comment: Adam fields)

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0859750	WC0805213	WC0805208
Sample Date	Client Info		10 Apr 2024	11 Mar 2024	16 Jan 2024
Machine Age	hrs	Client Info	40859	40128	39022
Oil Age	hrs	Client Info	3648	2919	1812
Oil Changed	Client Info		N/A	Not Changd	Not Changd
Sample Status			NORMAL	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>75	14	15	8
Chromium	ppm	ASTM D5185m	>8	<1	0	<1
Nickel	ppm	ASTM D5185m	>2	0	0	<1
Titanium	ppm	ASTM D5185m	>3	0	0	<1
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>15	3	1	3
Lead	ppm	ASTM D5185m	>18	3	2	4
Copper	ppm	ASTM D5185m	>80	25	27	18
Tin	ppm	ASTM D5185m	>14	<1	0	1
Vanadium	ppm	ASTM D5185m		0	0	<1
Cadmium	ppm	ASTM D5185m		0	0	<1

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		118	111	153
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		99	95	95
Manganese	ppm	ASTM D5185m		<1	0	2
Magnesium	ppm	ASTM D5185m		626	642	606
Calcium	ppm	ASTM D5185m		1556	1611	1432
Phosphorus	ppm	ASTM D5185m		687	621	678
Zinc	ppm	ASTM D5185m		819	796	799
Sulfur	ppm	ASTM D5185m		3033	2935	2617

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>20	5	3	5
Sodium	ppm	ASTM D5185m	>118	3	<1	4
Potassium	ppm	ASTM D5185m	>20	<1	0	4
Water	%	ASTM D6304	>0.1	NEG	NEG	NEG

INFRA-RED





	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		0.4	0.3	0.2
Nitration	Abs/cm	*ASTM D7624	>20	11.0	11.1	9.3
Sulfation	Abs/.1mm	*ASTM D7415	>30	23.3	23.4	22.0

FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	22.2	23.3	19.4
Base Number (BN)	mg KOH/g	ASTM D2896		8.01	7.05	8.29







OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.8	13.7	13.3

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0859750 **Received** : 23 Apr 2024
Lab Number : **06157891** **Tested** : 25 Apr 2024
Unique Number : 10993314 **Diagnosed** : 25 Apr 2024 - Sean Felton
Test Package : IND 2 (Additional Tests: KF)

MARATHON PETROLEUM CO.
 101 12TH ST
 CATLETTSBURG, KY
 US 41169
 Contact: CORY GUMBERT
 cagumbert@marathonpetroleum.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)