

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER BSD 40 7776972 (S/N 1011)

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Dec2023	Apr2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number Sample Date		Client Info		KCPA016347	KCPA009835	
•	bro	Client Info		03 Apr 2024 16305	22 Dec 2023 14610	
Machine Age	hrs hrs	Client Info		0	0	
Oil Age	1115	Client Info		Changed	N/A	
Oil Changed Sample Status		Ciletit iiiio		ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm		>50	1	0	
Chromium	ppm	ASTM D5185m	>10	<1	<1	
Nickel	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m	>3	<1	<1	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	2	1	
Lead	ppm	ASTM D5185m	>10	<1	0	
Copper	ppm	ASTM D5185m	>50	3	10	
Tin	ppm	ASTM D5185m	>10	<1	<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	0	10	
Molybdenum	ppm	ASTM D5185m	0	<1	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m	100	23	3	
Calcium	ppm	ASTM D5185m	0	4	<1	
Phosphorus	ppm	ASTM D5185m	0	3	1	
Zinc	ppm	ASTM D5185m	0	4	0	
Sulfur	ppm	ASTM D5185m	23500	20550	18726	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	2	
Sodium	ppm	ASTM D5185m		2	0	
Potassium	ppm	ASTM D5185m	>20	2	2	
Water	%	ASTM D6304	>0.05	0.014	0.004	
ppm Water	ppm	ASTM D6304	>500	146	40	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		57327	10464	
Particles >6µm		ASTM D7647	>1300	<u>^</u> 24868	△ 3133	
Particles >14µm		ASTM D7647	>80	<u>▲</u> 1769	<u>^</u> 219	
Particles >21µm		ASTM D7647	>20	<u>^</u> 225	<u></u> 53	
Particles >38μm		ASTM D7647	>4	1	1	
Particles >71μm		ASTM D7647		0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>△</u> 23/22/18	△ 21/19/15	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)				0 44	0.39	History

Acid Number (AN)


mg KOH/g ASTM D8045 1.0

0.39

0.44



OIL ANALYSIS REPORT





Certificate 12367

Laboratory Sample No.

Lab Number : 06158457

: KCPA016347 Unique Number : 10993880

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 23 Apr 2024 **Tested** : 25 Apr 2024 Diagnosed : 25 Apr 2024 - Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: BASDIX [WUSCAR] 06158457 (Generated: 04/25/2024 17:10:59) Rev: 1

Contact/Location: DAN YOUNG - BASDIX

DIXON, CA

US 95620

T:

F:

605 INDUSTRIAL WAY

Contact: DAN YOUNG

dan.young@basalite.com