




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
GENERAC 3164472 - BRADFORD DOWNS
 Component
Natural Gas Engine
 Fluid
SHELL ROTELLA T 15W40 (4 QTS)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

Metal levels are typical for a new component breaking in.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			WC0887886	WC0647401	WC0458272
Sample Date	Client Info			18 Apr 2024	11 Mar 2022	05 Apr 2021
Machine Age	hrs	Client Info		450	418	402
Oil Age	hrs	Client Info		0	0	0
Oil Changed	Client Info			Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Water	WC Method		>0.1	NEG	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	3	2
Chromium	ppm	ASTM D5185m	>4	0	<1	<1
Nickel	ppm	ASTM D5185m	>2	0	0	<1
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>3	0	<1	<1
Aluminum	ppm	ASTM D5185m	>9	3	4	2
Lead	ppm	ASTM D5185m	>30	2	2	2
Copper	ppm	ASTM D5185m	>35	0	<1	1
Tin	ppm	ASTM D5185m	>4	0	0	<1
Antimony	ppm	ASTM D5185m		---	---	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	<1

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	316	69	115	90
Barium	ppm	ASTM D5185m	0.0	0	1	0
Molybdenum	ppm	ASTM D5185m	1.2	91	74	62
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	24	120	266	666
Calcium	ppm	ASTM D5185m	2292	2502	1988	1581
Phosphorus	ppm	ASTM D5185m	1064	1146	1058	1082
Zinc	ppm	ASTM D5185m	1160	1410	1281	1314
Sulfur	ppm	ASTM D5185m	4996	4648	3465	2843

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+100	17	15	13
Sodium	ppm	ASTM D5185m		1	1	1
Potassium	ppm	ASTM D5185m	>20	0	2	1


INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0	0	0
Nitration	Abs/cm	*ASTM D7624	>20	7.7	7.3	6.3
Sulfation	Abs/.1mm	*ASTM D7415	>30	18.1	18.9	19.4

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	13.7	15.2	15.1
Base Number (BN)	mg KOH/g	ASTM D2896	10.1	6.9	8.5	---




OIL ANALYSIS REPORT


FT-IR (Direct Trend)



Base Number











Viscosity @ 100°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	15.7	14.2	14.5

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : WC0887886 Received : 24 Apr 2024
 Lab Number : 06158764 Tested : 25 Apr 2024
 Unique Number : 10994187 Diagnosed : 25 Apr 2024 - Wes Davis
 Test Package : MOB 1 (Additional Tests: TBN)

PIEDMONT GENERATOR
 7560 NC HWY 22 NORTH
 CLIMAX, NC
 US 27233

Contact: TERRY SHEPPARD
 terry1pg@bellsouth.net; bill3pg@bellsouth.net

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (336)685-4859

F: (336)685-5297