




# OIL ANALYSIS REPORT

## Sample Rating Trend



**NORMAL**



Machine Id

## GENERAC BERMUDA COMMONS

Component

Diesel Engine

Fluid

SHELL ROTELLA T 15W40 (3 GAL)

### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.

#### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>WC0887872</b>	WC0436232	WCM1383406
Sample Date	Client Info			<b>18 Apr 2024</b>	14 Jan 2021	11 Apr 2017
Machine Age	hrs	Client Info		<b>0</b>	0	0
Oil Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed	Client Info			<b>Changed</b>	Changed	Changed
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Fuel	WC Method	>5		<b>&lt;1.0</b>	<1.0	<1.0
Water	WC Method	>0.2		<b>NEG</b>	NEG	NEG
Glycol	WC Method			<b>NEG</b>	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>100	<b>5</b>	3	5
Chromium	ppm	ASTM D5185m	>20	<b>0</b>	<1	<1
Nickel	ppm	ASTM D5185m	>4	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m		<b>0</b>	0	0
Silver	ppm	ASTM D5185m	>3	<b>0</b>	<1	0
Aluminum	ppm	ASTM D5185m	>20	<b>&lt;1</b>	0	2
Lead	ppm	ASTM D5185m	>40	<b>1</b>	2	4
Copper	ppm	ASTM D5185m	>330	<b>0</b>	1	5
Tin	ppm	ASTM D5185m	>15	<b>0</b>	<1	0
Antimony	ppm	ASTM D5185m		<b>---</b>	<1	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	316	<b>74</b>	84	6
Barium	ppm	ASTM D5185m	0.0	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	1.2	<b>88</b>	54	62
Manganese	ppm	ASTM D5185m		<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185m	24	<b>70</b>	566	951
Calcium	ppm	ASTM D5185m	2292	<b>2405</b>	1555	1123
Phosphorus	ppm	ASTM D5185m	1064	<b>1127</b>	1055	1070
Zinc	ppm	ASTM D5185m	1160	<b>1362</b>	1270	1254
Sulfur	ppm	ASTM D5185m	4996	<b>4830</b>	2966	2964




CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<b>4</b>	0	3
Sodium	ppm	ASTM D5185m		<b>1</b>	1	2
Potassium	ppm	ASTM D5185m	>20	<b>&lt;1</b>	<1	0

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	>3	<b>0.1</b>	0.1	0
Nitration	Abs/cm	*ASTM D7624	>20	<b>7.9</b>	5.5	4.
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>17.7</b>	19.4	14.

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>14.0</b>	14.8	8.
Base Number (BN)	mg KOH/g	ASTM D2896	10.1	<b>6.9</b>	---	---











# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	15.7	13.0	13.7

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0887872      **Received** : 24 Apr 2024  
**Lab Number** : 06158765      **Tested** : 25 Apr 2024  
**Unique Number** : 10994188      **Diagnosed** : 25 Apr 2024 - Wes Davis  
**Test Package** : MOB 1 ( Additional Tests: TBN )

**PIEDMONT GENERATOR**  
 7560 NC HWY 22 NORTH  
 CLIMAX, NC  
 US 27233

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact: TERRY SHEPPARD  
 terry1pg@bellsouth.net; bill3pg@bellsouth.net  
 T: (336)685-4859  
 F: (336)685-5297