




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Area  
**FILMS DEPARTMENT SAMPLES**  
 Machine Id  
**DAVIS STAND 6B (S/N R5640)**  
 Component  
**Gearbox**  
 Fluid  
**TEXACO REGAL OIL R&O 220 (25 GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>WC0869535</b>	WC0821033	WC0757279
Sample Date	Client Info			<b>23 Apr 2024</b>	08 Oct 2023	04 Apr 2023
Machine Age	hrs	Client Info		<b>0</b>	0	0
Oil Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed	Client Info			<b>N/A</b>	N/A	N/A
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Water	WC Method		>0.2	<b>NEG</b>	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	<b>173</b>	131	54
Chromium	ppm	ASTM D5185m	>15	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m	>15	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m		<b>0</b>	0	0
Silver	ppm	ASTM D5185m		<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>25	<b>0</b>	4	0
Lead	ppm	ASTM D5185m	>100	<b>0</b>	<1	<1
Copper	ppm	ASTM D5185m	>200	<b>19</b>	26	24
Tin	ppm	ASTM D5185m	>25	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	<b>0</b>	<1	2
Barium	ppm	ASTM D5185m	0	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	0	<b>0</b>	0	<1
Manganese	ppm	ASTM D5185m		<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185m	0	<b>0</b>	0	<1
Calcium	ppm	ASTM D5185m	0	<b>5</b>	3	1
Phosphorus	ppm	ASTM D5185m	0	<b>230</b>	210	188
Zinc	ppm	ASTM D5185m	0	<b>22</b>	11	21
Sulfur	ppm	ASTM D5185m	4046	<b>8431</b>	8665	9234





CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	<b>&lt;1</b>	1	3
Sodium	ppm	ASTM D5185m		<b>3</b>	3	<1
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	<1	<1

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		<b>2872</b>	7187	3064
Particles >6µm		ASTM D7647	>5000	<b>552</b>	1482	723
Particles >14µm		ASTM D7647	>640	<b>33</b>	61	40
Particles >21µm		ASTM D7647	>160	<b>6</b>	15	9
Particles >38µm		ASTM D7647	>40	<b>0</b>	0	1
Particles >71µm		ASTM D7647	>10	<b>0</b>	0	1
Oil Cleanliness		ISO 4406 (c)	>--/19/16	<b>19/16/12</b>	20/18/13	19/17/12

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.65</b>	0.66	0.70




# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 220	207	201	185

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0869535  
**Lab Number** : 06159054  
**Unique Number** : 10994477  
**Test Package** : IND 2 ( Additional Tests: PrtCount )

**SEALED AIR CORP - CRYOVAC DIVISION**  
 1301 WEST MAGNOLIA AVE  
 IOWA PARK, TX  
 US 76367

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Contact: KEVIN KETCHERSID  
 kevin.a.ketchersid@sealedair.com

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

T: (940)592-2111

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (940)592-2513