


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

6985515 (S/N 2151)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS		œĸ	MC.		
	ZA\	uі.	\sim	\sim	\cdot

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Sep2021 J	an 2022 Jul 2022 Oct 203	22 Feb2023 Jul2023 Nov2023	Apr2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC128725	KC124390	KC100510
Sample Date		Client Info		16 Apr 2024	13 Nov 2023	11 Jul 2023
Machine Age	hrs	Client Info		15868	13785	11649
Oil Age	hrs	Client Info		3000	0	2500
Oil Changed		Client Info		Not Changd	N/A	Not Changd
Sample Status				NORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	<1	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	<1	0
Aluminum	ppm	ASTM D5185m	>10	0	1	1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	2	12	7
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	8	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	40	<1	6
Calcium	ppm	ASTM D5185m	2	<1	<1	0
Phosphorus	ppm	ASTM D5185m		0	0	0
Zinc	ppm	ASTM D5185m		6	0	8
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	0
Sodium	ppm	ASTM D5185m		7	0	0
Potassium	ppm	ASTM D5185m	>20	0	<1	2
Water	%	ASTM D6304	>0.05	0.019	0.011	0.007
ppm Water	ppm	ASTM D6304	>500	196	111	76.6
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1250	1398	23094
Particles >6µm		ASTM D7647	>1300	267	481	<u>▲</u> 4751
Particles >14μm		ASTM D7647	>80	24	68	▲ 312
Particles >21µm		ASTM D7647	>20	7	31	△ 97
Particles >38µm		ASTM D7647	>4	0	3	4
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/15/12	18/16/13	<u>22/19/15</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Acid Number (AN)

mg KOH/g ASTM D8045 0.4

0.39

0.46

0.45



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number : 06159122 Unique Number : 10994545

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KC128725 Received : 24 Apr 2024 **Tested** : 25 Apr 2024

Diagnosed : 26 Apr 2024 - Jonathan Hester

Test Package : IND 2 To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

TECHNIP FMC

CHARLEROI, PA

US 15022

T:

F:

12 ARENTZEN BLVD

Contact: Service Manager