




OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id
SOUTH 1 (S/N 003-82191)
 Component
Compressor
 Fluid
USPI 1542-32 (--- GAL)

DIAGNOSIS

- Recommendation**
We recommend an early resample to monitor this condition.
- Wear**
The iron level is abnormal.
- Contamination**
There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.
- Fluid Condition**
The oil viscosity is higher than normal. Confirmed. Additives confirmed. Confirm oil type. The AN level is acceptable for this fluid.

SAMPLE INFORMATION	method	limit/base	current	history1	history2
Sample Number	Client Info		USPM36816	USPM31299	USPM27400
Sample Date	Client Info		23 Apr 2024	18 Nov 2023	13 Jul 2023
Machine Age	hrs	Client Info	0	0	0
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ATTENTION	ABNORMAL

WEAR METALS	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	▲ 127	7	<1
Chromium	ppm	ASTM D5185m >10	0	0	0
Nickel	ppm	ASTM D5185m	0	0	0
Titanium	ppm	ASTM D5185m	0	0	<1
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	1	0	<1
Lead	ppm	ASTM D5185m >25	0	0	<1
Copper	ppm	ASTM D5185m >50	0	0	37
Tin	ppm	ASTM D5185m >15	0	<1	<1
Antimony	ppm	ASTM D5185m	---	---	---
Vanadium	ppm	ASTM D5185m	0	0	<1
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	<1	0
Barium	ppm	ASTM D5185m	0	0	638
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	<1	0	<1
Magnesium	ppm	ASTM D5185m	<1	<1	3
Calcium	ppm	ASTM D5185m	3	<1	4
Phosphorus	ppm	ASTM D5185m	851	● 1384	4
Zinc	ppm	ASTM D5185m	29	0	74
Sulfur	ppm	ASTM D5185m	593	33	559






CONTAMINANTS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	3	3	<1
Sodium	ppm	ASTM D5185m	16	0	17
Potassium	ppm	ASTM D5185m >20	<1	0	4
Water	%	ASTM D6304 >0.1	0.039	0.040	▲ 0.600
ppm Water	ppm	ASTM D6304 >1000	396	400.5	▲ 6007.4

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	2021	2959	▲ 26446
Particles >6µm	ASTM D7647	>2500	550	801	▲ 7461
Particles >14µm	ASTM D7647	>320	48	57	▲ 585
Particles >21µm	ASTM D7647	>80	13	12	▲ 160
Particles >38µm	ASTM D7647	>20	1	2	6
Particles >71µm	ASTM D7647	>4	0	2	0
Oil Cleanliness	ISO 4406 (c)	>20/18/15	18/16/13	19/17/13	▲ 22/20/16

FLUID DEGRADATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.33	0.20	0.32




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	119.6	100.6	39.2

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : USPM36816
 Lab Number : 06159124
 Unique Number : 10994547
 Test Package : IND 2
 Received : 24 Apr 2024
 Tested : 29 Apr 2024
 Diagnosed : 29 Apr 2024 - Doug Bogart

JBS - BEARDSTOWN
 8295 ARENZVILLE RD
 BEARDSTOWN, IL
 US 62618
 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: