




# OIL ANALYSIS REPORT

Machine Id  
**WVTM01BE**  
 Component  
**Biogas Engine**  
 Fluid  
**MOBIL Pegasus™ 605 Ultra 40 (--- GAL)**

Sample Rating Trend



## DIAGNOSIS

### ▲ Recommendation

Oil and filter change at the time of sampling has been noted. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. ( Customer Sample Comment: Oil and filters changed )

### ▲ Wear

The tin level is severe.

### ▲ Contamination

Elemental level of silicon (Si) above normal.

### ▲ Fluid Condition

The BN level is low. The AN level is acceptable for this fluid. The oil is no longer serviceable.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0895542</b>	WC0895541	WC0895537
Sample Date	Client Info		<b>22 Apr 2024</b>	19 Apr 2024	15 Apr 2024
Machine Age	hrs	Client Info	<b>115668</b>	115595	115499
Oil Age	hrs	Client Info	<b>836</b>	763	667
Oil Changed	Client Info		<b>Changed</b>	Not Changd	Not Changd
Sample Status			<b>SEVERE</b>	SEVERE	SEVERE

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<b>&lt;1.0</b>	<1.0	<1.0
Water	WC Method		<b>NEG</b>	NEG	NEG
Glycol	WC Method		<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >14	<b>8</b>	6	6
Chromium	ppm	ASTM D5185m >3	<b>&lt;1</b>	<1	0
Nickel	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >5	<b>4</b>	3	3
Lead	ppm	ASTM D5185m >8	<b>3</b>	1	2
Copper	ppm	ASTM D5185m >5	<b>2</b>	0	2
Tin	ppm	ASTM D5185m >3	<b>▲ 6</b>	▲ 5	▲ 4
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>44</b>	40	45
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>4</b>	1	1
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m	<b>31</b>	21	20
Calcium	ppm	ASTM D5185m	<b>1733</b>	1738	1697
Phosphorus	ppm	ASTM D5185m	<b>431</b>	414	424
Zinc	ppm	ASTM D5185m	<b>658</b>	608	606
Sulfur	ppm	ASTM D5185m	<b>5601</b>	5900	6062

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >180	<b>▲ 220</b>	▲ 207	▲ 186
Sodium	ppm	ASTM D5185m >20	<b>2</b>	1	2
Potassium	ppm	ASTM D5185m >20	<b>&lt;1</b>	0	2

## INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	<b>0</b>	0	0
Nitration	Abs/cm	*ASTM D7624	<b>4.1</b>	4.1	4.1
Sulfation	Abs/.1mm	*ASTM D7415	<b>28.3</b>	27.4	26.7


## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	<b>14.7</b>	14.1	13.8
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>2.71</b>	2.67	2.44
Base Number (BN)	mg KOH/g	ASTM D2896 5.7	<b>▲ 1.69</b>	▲ 1.70	▲ 1.83




# OIL ANALYSIS REPORT


## ▲ Non-ferrous Metals




## FT-IR (Direct Trend)




## Acid Number



## FT-IR (Direct Trend)











## Acid Number



VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	<b>LIGHT</b>	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	<b>NEG</b>	NEG	NEG	
Free Water	scalar	*Visual	<b>NEG</b>	NEG	NEG	

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D445	15	<b>15.1</b>	15.1	15.0

## GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
 Sample No. : WC0895542  
 Lab Number : 06159301  
 Unique Number : 10994724  
 Test Package : MOB 2

Received : 24 Apr 2024  
 Tested : 25 Apr 2024  
 Diagnosed : 26 Apr 2024 - Don Baldrige

**EDL NA Recips-Watervliet**  
 Watervliet Powerstation, 3563 Hennessey Road  
 Watervliet, MI  
 US 49098

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact: Scott Eastman  
 scott.eastman@edlenergy.com

T:  
 F: