

## **OIL ANALYSIS REPORT**

Sample Rating Trend

NORMAL

## Machine Id 041624S-02

Component Fluid Fluid {not provided} (--- GAL)

## DIAGNOSIS

Recommendation


This is a baseline read-out on the submitted sample.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC06159583		
Sample Date		Client Info		16 Apr 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATION	۷	method	limit/base	current	history1	history2
Water		WC Method		NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m		9		
Chromium	ppm	ASTM D5185m		0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m		0		
Lead	ppm	ASTM D5185m		0		
Copper	ppm	ASTM D5185m		0		
Tin	ppm	ASTM D5185m		<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		<1		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		3		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		1441		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m		<1		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	<1		
SAMPLE IMAGES	\$	method	limit/base	current	history1	history2
Color				no image	no image	no image
Bottom				no image	no image	no image



## **OIL ANALYSIS REPORT**

GRAPHS



Contact/Location: BRYAN DOLE - XAEMID Page 2 of 2