

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



041624S-01 Compor Fluid Fluid

{not provided} (--- GAL)

Machine Id

Recommendation

This is a baseline read-out on the submitted sample.

				Apr2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC06159602		
Sample Date		Client Info		16 Apr 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATION	V	method	limit/base	current	history1	history2
Water		WC Method		NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m		7		
Chromium	ppm	ASTM D5185m		0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m		2		
Lead	ppm	ASTM D5185m		0		
Copper	ppm	ASTM D5185m		0		
Tin	ppm	ASTM D5185m		<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
ADDITIVES Boron	ppm	method ASTM D5185m	limit/base	current 0	history1	history2
	ppm		limit/base			
Boron		ASTM D5185m	limit/base	0		
Boron Barium	ppm	ASTM D5185m ASTM D5185m	limit/base	0 0		
Boron Barium Molybdenum	ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m	limit/base	0 0 0		
Boron Barium Molybdenum Manganese	ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	limit/base	0 0 0		
Boron Barium Molybdenum Manganese Magnesium	ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	limit/base	0 0 0 0 <1		
Boron Barium Molybdenum Manganese Magnesium Calcium	ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	limit/base	0 0 0 0 <1		
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus	ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	limit/base	0 0 0 0 <1 0 <1		
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc	ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	limit/base	0 0 0 0 <1 0 <1		
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur	ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m		0 0 0 0 <1 0 <1 0		
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS	ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m		0 0 0 0 <1 0 <1 0 current	 history1	
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS	ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m	limit/base	0 0 0 0 <1 0 <1 0 current	 history1	history2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS Silicon Sodium	ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m	limit/base	0 0 0 0 <1 0 <1 0 current	history1	history2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINANTS Silicon Sodium Potassium	ppm ppm ppm ppm ppm ppm ppm ppm	ASTM D5185m	limit/base	0 0 0 0 0 <1 0 <1 0 current 0 0	history1	history2



OIL ANALYSIS REPORT



Certificate 12367

Laboratory: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : WC06159602 **Lab Number** : 06159602 $\textbf{Unique Number} \quad : 10995025$

Test Package : TEST (Additional Tests: ICP)

Received : 24 Apr 2024 Tested : 26 Apr 2024 Diagnosed

: 26 Apr 2024 - Jonathan Hester

US 48642 Contact: BRYAN DOLE bdole@xaerusfluids.com T:

XAERUS FLUIDS

MIDLAND, MI

2825 SCHUETTE RD

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: XAEMID [WUSCAR] 06159602 (Generated: 04/26/2024 13:21:16) Rev: 1

Contact/Location: BRYAN DOLE - XAEMID

F: