


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER 6547246

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil. Elemental level of silicon (Si) above normal.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Augzuzz	Aprzuz4		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA013731	KCP50619	
Sample Date		Client Info		18 Apr 2024	24 Aug 2022	
Machine Age	hrs	Client Info		11364	8284	
Oil Age	hrs	Client Info		3080	8284	
Oil Changed		Client Info		Changed	Changed	
Sample Status				ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	1	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	<1	<1	
Aluminum	ppm	ASTM D5185m	>10	2	1	
Lead	ppm	ASTM D5185m	>10	1	0	
Copper	ppm	ASTM D5185m	>50	8	6	
Tin	ppm	ASTM D5185m	>10	1	<1	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	10	68	
Molybdenum	ppm	ASTM D5185m	0	1	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	100	40	63	
Calcium	ppm	ASTM D5185m	0	4	2	
Phosphorus	ppm	ASTM D5185m	0	12	0	
Zinc	ppm		0	7	5	
Sulfur	ppm	ASTM D5185m	23500	21639	17814	
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	△ 36	<1	
Sodium	ppm	ASTM D5185m		9	<1	
Potassium	ppm	ASTM D5185m	>20	3	1	
Water	%	ASTM D6304	>0.05	0.023	0.009	
ppm Water	ppm	ASTM D6304	>500	237	97.6	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		6938	3912	
Particles >6µm		ASTM D7647	>1300	<u> </u>	656	
Particles >14μm		ASTM D7647	>80	<u>91</u>	25	
Particles >21µm		ASTM D7647	>20	<u> </u>	8	
Particles >38μm		ASTM D7647	>4	1	0	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	20/18/14	19/17/12	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.37	0.43	



OIL ANALYSIS REPORT







Laboratory Sample No.

: KCPA013731 Lab Number : 06159789 Unique Number : 10995212

Received : 24 Apr 2024 Tested Diagnosed

: 25 Apr 2024 : 26 Apr 2024 - Don Baldridge 6570 BERGESEN DR KELSEYVILLE, CA US 95451

Contact: Service Manager

Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Service Manager - LAKKEL

T:

F: