




# FUEL REPORT

Sample Rating Trend



**WATER**



Area

[PMOAS3372430]

Machine Id

**SD300 FREDERICK DR (S/N 2103231)**

Component

**Diesel Fuel**

Fluid

**No.2 DIESEL FUEL (LOW-SULPHUR) (1000 GAL)**

## DIAGNOSIS

### Recommendation

We advise that you follow the water drain-off procedure for this component.

### Corrosion

All metal levels are normal indicating no corrosion in the system.

### Contaminants

Free water present. There is no bacteria or fungus (yeast and/or mold) present in the sample.

### Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>DC0034674</b>	DC0029069	DC0019545
Sample Date	Client Info			<b>19 Apr 2024</b>	04 Apr 2023	19 Apr 2022
Machine Age	hrs	Client Info		<b>603</b>	561	593
Sample Status				<b>ABNORMAL</b>	NORMAL	NORMAL

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
ASTM Color	scalar	*ASTM D1500		<b>L5.5</b>	L4.5	L4.5
Visc @ 40°C	cSt	ASTM D445	3.0	<b>2.42</b>	2.48	2.4

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	250	<b>0</b>	5	3
Sulfur (UVF)	ppm	ASTM D5453		<b>15</b>	14	13

IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	<b>36.4</b>	36.4	36.2

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<b>0</b>	0	0
Sodium	ppm	ASTM D5185m	<0.1	<b>0</b>	0	<1
Potassium	ppm	ASTM D5185m	<0.1	<b>0</b>	0	0
Water	%	ASTM D6304	<0.05	<b>0.007</b>	0.005	0.004
ppm Water	ppm	ASTM D6304	<500	<b>79</b>	53.2	48.2
% Gasoline	%	*In-House	<0.50	<b>0.0</b>	0.0	0.0
% Biodiesel	%	*In-House	<20.0	<b>0.0</b>	0.0	0.0



FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	---	7461	5126
Particles >6µm		ASTM D7647	>640	---	1625	1650
Particles >14µm		ASTM D7647	>80	---	106	162
Particles >21µm		ASTM D7647	>20	---	29	27
Particles >38µm		ASTM D7647	>4	---	1	2
Particles >71µm		ASTM D7647	>3	---	0	0
Oil Cleanliness		ISO 4406 (c)	>18/16/13	---	20/18/14	20/18/15

MICROBIAL		method	limit/base	current	history1	history2
Bacteria	CFU/ml	WC-Method	>=100000	<b>0</b>	---	---
Yeast	CFU/ml	WC-Method	>=100000	<b>0</b>	---	---
Mold	Colonies	WC-Method	MODER	---	---	---

HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	<b>0</b>	0	<1
Nickel	ppm	ASTM D5185m	<0.1	<b>0</b>	0	0
Lead	ppm	ASTM D5185m	<0.1	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185m	<0.1	<b>0</b>	0	0
Iron	ppm	ASTM D5185m	<0.1	<b>0</b>	0	0
Calcium	ppm	ASTM D5185m	<0.1	<b>0</b>	0	0
Magnesium	ppm	ASTM D5185m	<0.1	<b>0</b>	0	0
Phosphorus	ppm	ASTM D5185m	<0.1	<b>0</b>	0	0
Zinc	ppm	ASTM D5185m	<0.1	<b>0</b>	0	0




# FUEL REPORT



SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : DC0034674  
**Lab Number** : 06159975  
**Unique Number** : 10995398  
**Test Package** : DF-5 ( Additional Tests: API, Bacteria, Cetane, Fuel, PrtCount, Screen )

**Received** : 24 Apr 2024  
**Tested** : 06 May 2024  
**Diagnosed** : 06 May 2024 - Doug Bogart

**KELLY GENERATOR & EQUIPMENT INC**  
 1955 DALE LN  
 OWINGS, MD  
 US 20736

Contact: LESLIE SNURR  
 LSNURR@KGE.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (410)257-5225

F: (410)257-5227