


FUEL REPORT

[PMOAS3372437] **LANDFALL 2 (S/N I120384917)**

Diesel Fuel

No.2 DIESEL FUEL (LOW-SULPHUR) (--- QTS)





Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is no Bacteria, Yeast and/or Fungus indicated in the sample. The water content is negligible. There is no indication of any contamination in the fuel.


Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

QTS)		Apr202	1 Apr2022	Apr2023 A	ipr2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		DC0034668	DC0025184	DC0019547
Sample Date		Client Info		12 Apr 2024	06 Apr 2023	20 Apr 2022
Machine Age	hrs	Client Info		0	564	506
Sample Status				NORMAL	NORMAL	NORMAL
PHYSICAL PROP	PERTIES	method	limit/base	current	history1	history2
ASTM Color	scalar	*ASTM D1500		L4.5	L4.5	L3.5
Visc @ 40°C	cSt	ASTM D445	3.0	2.4	2.53	2.4
SULFUR CONTE	NT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	250	0	0	38
Sulfur (UVF)	ppm	ASTM D5453		25	32	42
IGNITION QUALIT	ΓΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	36.9	36.8	36.9
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0	<1	<1
Sodium	ppm	ASTM D5185m	< 0.1	0	0	0
Potassium	ppm	ASTM D5185m	<0.1	0	<1	0
Water	%	ASTM D6304	< 0.05	0.005	0.003	0.003
ppm Water	ppm	ASTM D6304	< 500	56	36.9	28.3
% Gasoline	%	*In-House	< 0.50	0.0	0.0	0.0
% Biodiesel	%	*In-House	<20.0	0.0	0.0	0.0
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500		3401	4517
Particles >6μm		ASTM D7647	>640		1027	1137
Particles >14μm		ASTM D7647	>80		95	73
Particles >21µm		ASTM D7647	>20		22	17
Particles >38µm		ASTM D7647	>4		0	1
Particles >71μm		ASTM D7647			0	0
Oil Cleanliness		ISO 4406 (c)	>18/16/13		19/17/14	19/17/13
HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	0	0	0
Nickel	ppm	ASTM D5185m	< 0.1	0	0	0
Lead	ppm	ASTM D5185m	<0.1	0	0	0
Vanadium	ppm	ASTM D5185m	< 0.1	0	0	0
Iron	ppm	ASTM D5185m	<0.1	0	<1	0
Calcium	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	<0.1	0	<1	0
Phosphorus	ppm	ASTM D5185m		0	6	2
Zinc	ppm	ASTM D5185m	<0.1	0	0	0



FUEL REPORT





Viscosity	@ 40°C		
Abnormal			
Base Abnormal			
1-			
Apr21/21	Apr20/22	Apr6/23 + -	Apr12/24

GRAPHS Pensky-Martens Flash Point (°C)



Certificate 12367

Laboratory

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 **Sample No.** : DC0034668 Lab Number : 06159977

Unique Number : 10995400

Received Tested Diagnosed

: 24 Apr 2024 : 06 May 2024

: 06 May 2024 - Doug Bogart Test Package: DF-5 (Additional Tests: API, Cetane, Fuel, PrtCount, Screen)

OWINGS, MD US 20736 Contact: LESLIE SNURR LSNURR@KGE.COM

T: (410)257-5225

1955 DALE LN

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (410)257-5227

KELLY GENERATOR & EQUIPMENT INC