




COOLANT REPORT

Sample Rating Trend



NORMAL



Area
[PMOAS3372437]
 Machine Id
LANDFALL 2 (S/N I120384917)
 Component
Coolant
 Fluid
CONVENTIONAL COOLANT (--- QTS)

DIAGNOSIS

Recommendation

The fluid is suitable for further service.

Contaminants

There is no indication of any contamination in the coolant.

Coolant Condition

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.







SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		DC0035063	DC0026350	DC0017053
Sample Date	Client Info		12 Apr 2024	06 Apr 2023	20 Apr 2022
Machine Age	hrs	Client Info	0	564	506
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	Not Changd	Not Changd
Sample Status			NORMAL	NORMAL	NORMAL

PHYSICAL TEST RESULTS








	method	limit/base	current	history1	history2
Glycol Type	FT-IR		---	---	---
Specific Gravity	*ASTM D1298		1.069	1.070	1.070
pH	Scale 0-14 ASTM D1287		7.98	8.10	8.29
Nitrites	ppm AP-053:2009		636	788	936
Reserve Alkalinity	Scale 0-20 *ASTM D1121		---	---	---
Percentage Glycol	% ASTM D3321		51.6	52.8	52.3
Freezing Point	°F ASTM D3321		-38	-40	-40
Total Dissolved Solids			336.0	418.0	447.5
Carboxylate			n/a	n/a	n/a

VISUAL

	method	limit/base	current	history1	history2
Coolant Color	*Visual		Green	Yellow	Green
Coolant Appearance	*Visual	Clear	normal	normal	normal
Color					
Bottom					



COOLANT REPORT



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : DC0035063
Lab Number : 06159991
Unique Number : 10995414
Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType)

KELLY GENERATOR & EQUIPMENT INC
 1955 DALE LN
 OWINGS, MD
 US 20736

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact: LESLIE SNURR
 LSNURR@KGE.COM
 T: (410)257-5225
 F: (410)257-5227