

OIL ANALYSIS REPORT

Sample Rating Trend



Area S-460 Machine Id KAESER 1251 - JOLIET PATTERN

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	NATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UDI0000107	UCH05785086	
Sample Date		Client Info		18 Apr 2024	21 Feb 2023	
Machine Age	hrs	Client Info		2301	1384	
Oil Age	hrs	Client Info		4127	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	NORMAL	
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.05	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	2	0	
Lead	ppm	ASTM D5185m	>10	<1	0	
Copper	ppm	ASTM D5185m	>50	2	3	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m		<1	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	90	50	34	
Calcium	ppm	ASTM D5185m	2	0	0	
Phosphorus	ppm	ASTM D5185m		4	4	
Zinc	ppm	ASTM D5185m		2	0	
Sulfur	ppm	ASTM D5185m		21843	19865	
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	
Sodium	ppm	ASTM D5185m		19	11	
Potassium	ppm	ASTM D5185m	>20	3	<1	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.33	0.32	



OIL ANALYSIS REPORT



	VISUAL		method	limit/base	current	history1	history2
	White Metal	scalar	*Visual	NONE	NONE	NONE	
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
	Precipitate	scalar	*Visual	NONE	NONE	NONE	
	Silt	scalar	*Visual	NONE	NONE	NONE	
	Debris	scalar	*Visual	NONE	NONE	VLITE	
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
Apr18/24	Appearance	scalar	*Visual	NORML	NORML	NORML	
Apr	Odor	scalar	*Visual	NORML	NORML	NORML	
	Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	
	Free Water	scalar	*Visual		NEG	NEG	
	FLUID PROPER	TIES	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445	46	43.8	44.1	
	SAMPLE IMAGE	S	method	limit/base	current	history1	history2
Apr18/24 +	Color				a.		no image
	Bottom				Cont		no image
	Non-ferrous Meta	ıls		Apr18/24			
				Apr18/24			
	Viscosity @ 40°C				Acid Number		
	Abnormal			(B/H0.40	Base		
	S0 - P Base			Q U.4U			
	€ 45			y bi 0.30 a 0.20 y bi 0.20 y bi 0.20 V 0.00 V 0.00 V 0.00			
	40 - Abnormal				,		
	35						
	Feb21/23			Apr1 8/24	Feb 21/23		
	- Leit			Ap	E.		
Laboratory Sample No.	: WearCheck USA - 5(: UDI0000107 : 06160524)1 Madiso Recei Teste	ived : 25	, NC 27513 5 Apr 2024 5 Apr 2024	DELTA		WNERS GRON TISS STREE RS GROVE,

S

Contact/Location: STEVE KORZUN - UCDELDOW