


OIL ANALYSIS REPORT

Area
S-460
Machine Id

KAESER 1468 - OWENS & MINOR MEDICAL

Component





Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


			Sep2020	Apr2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UDI0000115	UCH05079207	
Sample Date		Client Info		12 Apr 2024	18 Sep 2020	
Machine Age	hrs	Client Info		16532	18811	
Oil Age	hrs	Client Info		3000	0	
Oil Changed		Client Info		Changed	Changed	
Sample Status				NORMAL	ABNORMAL	
CONTAMINATION	V	method	limit/base	current	history1	history2
Water		WC Method	>0.05	NEG	NEG	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2	2	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	2	0	
Lead	ppm	ASTM D5185m	>10	<1	0	
Copper	ppm	ASTM D5185m	>50	4	23	
Tin	ppm	ASTM D5185m	>10	<1	<1	
Antimony	ppm	ASTM D5185m			3	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	11	
Barium	ppm	ASTM D5185m	90	3	0	
Molybdenum	ppm	ASTM D5185m		<1	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m	90	41	9	
Calcium	ppm	ASTM D5185m	2	0	<1	
Phosphorus	ppm	ASTM D5185m		0	4	
Zinc	ppm	ASTM D5185m		4	10	
Sulfur	ppm	ASTM D5185m		22300	16445	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	0	
Sodium	ppm	ASTM D5185m		18	3	
Potassium	ppm	ASTM D5185m	>20	3	<1	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.39	0.351	





OIL ANALYSIS REPORT















Certificate 12367

Laboratory

Sample No. Lab Number : 06160544 Unique Number : 10995967

Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : UDI0000115

Received : 25 Apr 2024 **Tested** Diagnosed

: 26 Apr 2024 : 26 Apr 2024 - Sean Felton

DELTA INDUSTRIES - DOWNERS GROVE 2201 CURTISS STREET

DOWNERS GROVE, IL US 60515

Contact: MICHAEL FERRIS

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (630)960-3931