




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**4EK05286**

Component  
**Biogas Engine**

Fluid  
**MAHLER Q8 Mahler G8 SAE 40 (--- GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>WC0880263</b>	WC0880265	WC0880270
Sample Date	Client Info			<b>23 Apr 2024</b>	16 Apr 2024	11 Apr 2024
Machine Age	hrs	Client Info		<b>82851</b>	82739	82615
Oil Age	hrs	Client Info		<b>212</b>	100	483
Oil Changed	Client Info			<b>N/A</b>	Changed	N/A
Sample Status				<b>NORMAL</b>	NORMAL	SEVERE

CONTAMINATION		method	limit/base	current	history1	history2
Fuel	WC Method	>4.0		<b>&lt;1.0</b>	<1.0	<1.0
Water	WC Method	>0.1		<b>NEG</b>	NEG	NEG
Glycol	WC Method			<b>NEG</b>	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>45	<b>5</b>	3	14
Chromium	ppm	ASTM D5185m	>2	<b>&lt;1</b>	0	2
Nickel	ppm	ASTM D5185m	>2	<b>1</b>	0	1
Titanium	ppm	ASTM D5185m		<b>&lt;1</b>	0	<1
Silver	ppm	ASTM D5185m	>5	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>10	<b>3</b>	2	3
Lead	ppm	ASTM D5185m	>5	<b>&lt;1</b>	0	1
Copper	ppm	ASTM D5185m	>14	<b>2</b>	1	7
Tin	ppm	ASTM D5185m	>13	<b>2</b>	2	4
Vanadium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	0
Cadmium	ppm	ASTM D5185m		<b>&lt;1</b>	0	<1

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>0</b>	0	1
Barium	ppm	ASTM D5185m		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>&lt;1</b>	0	1
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1	1
Magnesium	ppm	ASTM D5185m		<b>5</b>	4	6
Calcium	ppm	ASTM D5185m		<b>2185</b>	2143	2443
Phosphorus	ppm	ASTM D5185m		<b>412</b>	348	419
Zinc	ppm	ASTM D5185m		<b>450</b>	363	458
Sulfur	ppm	ASTM D5185m		<b>3936</b>	3313	5747

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>200	<b>90</b>	89	▲ 318
Sodium	ppm	ASTM D5185m		<b>&lt;1</b>	2	2
Potassium	ppm	ASTM D5185m	>20	<b>&lt;1</b>	0	2


INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		<b>0</b>	0	0
Nitration	Abs/cm	*ASTM D7624	>20	<b>4.3</b>	4.5	4.7
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>17.8</b>	18.1	23.8

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>9.2</b>	9.3	10.2
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>1.27</b>	1.13	2.33
Base Number (BN)	mg KOH/g	ASTM D2896	8.0	<b>6.17</b>	6.14	4.14




# OIL ANALYSIS REPORT


FT-IR (Direct Trend)




Acid Number



Base Number




Viscosity @ 100°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.2	13.0	13.1

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0880263  
**Lab Number** : 06160572  
**Unique Number** : 10995995  
**Test Package** : MOB 2

**Received** : 25 Apr 2024  
**Tested** : 26 Apr 2024  
**Diagnosed** : 26 Apr 2024 - Sean Felton

**BI-COUNTY**  
 3214 DOVER RD  
 WOODLAWN, TN  
 US 37191

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact: KEVIN WEAVER  
kevin.weaver@cubedistrictenergy.com

T:  
F: