




OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Machine Id

LGS00178

Component

Biogas Engine

Fluid

MAHLER Q8 Mahler G8 SAE 40 (141 GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

The lead level is abnormal. The copper level is abnormal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0880264	WC0880266	WC0880271
Sample Date	Client Info		23 Apr 2024	16 Apr 2024	11 Apr 2024
Machine Age	hrs	Client Info	67186	0	66928
Oil Age	hrs	Client Info	431	300	173
Oil Changed		Client Info	N/A	Not Changd	N/A
Sample Status			ABNORMAL	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Water	WC Method	>0.1	NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>45	5	2	<1
Chromium	ppm	ASTM D5185m	>2	<1	0	<1
Nickel	ppm	ASTM D5185m	>2	1	0	<1
Titanium	ppm	ASTM D5185m		<1	0	<1
Silver	ppm	ASTM D5185m	>5	0	0	0
Aluminum	ppm	ASTM D5185m	>10	5	3	2
Lead	ppm	ASTM D5185m	>5	▲ 5	2	2
Copper	ppm	ASTM D5185m	>14	▲ 16	8	5
Tin	ppm	ASTM D5185m	>13	4	2	2
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		<1	0	<1

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	<1
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		6	4	6
Calcium	ppm	ASTM D5185m		2258	2191	2356
Phosphorus	ppm	ASTM D5185m		408	343	419
Zinc	ppm	ASTM D5185m		478	375	480
Sulfur	ppm	ASTM D5185m		5330	4545	4562

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>200	183	147	118
Sodium	ppm	ASTM D5185m		1	2	0
Potassium	ppm	ASTM D5185m	>20	1	0	1

INFRA-RED

	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		0.1	0	0
Nitration	Abs/cm	*ASTM D7624	>20	4.9	4.8	4.8
Sulfation	Abs/.1mm	*ASTM D7415	>30	22.5	21.7	19.3


FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	10.2	9.8	9.1
Acid Number (AN)	mg KOH/g	ASTM D8045		1.62	1.50	1.18
Base Number (BN)	mg KOH/g	ASTM D2896	8.0	4.47	4.35	5.72




OIL ANALYSIS REPORT


Non-ferrous Metals




FT-IR (Direct Trend)




Acid Number



Base Number











Viscosity @ 100°C



PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.2	13.8	13.6

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : WC0880264

Lab Number : 06160573

Unique Number : 10995996

Test Package : MOB 2

Received : 25 Apr 2024

Tested : 26 Apr 2024

Diagnosed : 26 Apr 2024 - Sean Felton

BI-COUNTY

3214 DOVER RD

WOODLAWN, TN

US 37191

Contact: KEVIN WEAVER

kevin.weaver@cubedistrictenergy.com

T:

F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)