




# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Area  
**UTILITIES**  
 Machine Id  
**OS1-GEN**  
 Component  
**Auxiliary Power Unit Natural Gas Engine**  
 Fluid  
**DIESEL ENGINE OIL SAE 5W30 (5 QTS)**

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a light concentration of water present in the oil.

### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is acceptable for the time in service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0840375</b>	WC0840386	WC0840390
Sample Date	Client Info		<b>22 Apr 2024</b>	22 Jan 2024	13 Nov 2023
Machine Age	hrs	Client Info	<b>224</b>	221	217
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	NORMAL	NORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>7</b>	4	5
Chromium	ppm	ASTM D5185m >4	<b>&lt;1</b>	<1	0
Nickel	ppm	ASTM D5185m >2	<b>&lt;1</b>	0	0
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Silver	ppm	ASTM D5185m >3	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >9	<b>3</b>	1	1
Lead	ppm	ASTM D5185m >30	<b>11</b>	10	9
Copper	ppm	ASTM D5185m >35	<b>3</b>	2	3
Tin	ppm	ASTM D5185m >4	<b>&lt;1</b>	<1	0
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 250	<b>139</b>	120	148
Barium	ppm	ASTM D5185m 10	<b>0</b>	0	7
Molybdenum	ppm	ASTM D5185m 100	<b>121</b>	116	130
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Magnesium	ppm	ASTM D5185m 450	<b>522</b>	516	517
Calcium	ppm	ASTM D5185m 3000	<b>1059</b>	1071	1113
Phosphorus	ppm	ASTM D5185m 1150	<b>681</b>	655	728
Zinc	ppm	ASTM D5185m 1350	<b>775</b>	772	758
Sulfur	ppm	ASTM D5185m 4250	<b>3031</b>	2406	2554

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >+100	<b>13</b>	10	11
Sodium	ppm	ASTM D5185m	<b>5</b>	2	0
Potassium	ppm	ASTM D5185m >20	<b>1</b>	2	1
Water	%	ASTM D6304 >0.1	<b>▲ 0.238</b>	---	---
ppm Water	ppm	ASTM D6304 >1000	<b>▲ 2380</b>	---	---

## INFRA-RED






	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	<b>0.1</b>	0	0
Nitration	Abs/cm	*ASTM D7624 >20	<b>5.6</b>	5.2	5.0
Sulfation	Abs/.1mm	*ASTM D7415 >30	<b>14.1</b>	14.5	14.8

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	<b>8.5</b>	8.5	8.3
Base Number (BN)	mg KOH/g	ASTM D2896 8.5	<b>7.29</b>	7.74	7.46







# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	NONE	
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
Precipitate	scalar	*Visual	NONE	NONE	NONE	
Silt	scalar	*Visual	NONE	NONE	NONE	
Debris	scalar	*Visual	NONE	NONE	NONE	
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
Appearance	scalar	*Visual	NORML	NORML	NORML	
Odor	scalar	*Visual	NORML	NORML	NORML	
Emulsified Water	scalar	*Visual	>0.1	▲ 0.2%	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D445	10.9	9.7	9.8	9.9

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0840375  
**Lab Number** : 06160578  
**Unique Number** : 10996001  
**Test Package** : IND 2 ( Additional Tests: Glycol, KF )  
**Received** : 25 Apr 2024  
**Tested** : 26 Apr 2024  
**Diagnosed** : 26 Apr 2024 - Sean Felton

**TORAY CARBON FIBERS AMERICA INC**  
 2202 MOORE DUNCAN HWY  
 MOORE, SC  
 US 29369  
 Contact: Kirk Stilling  
 Kirk.stilling@toraycma.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)