

OIL ANALYSIS REPORT

WHEY
Machine to
PO02PP11BB01

Bearing

MOBIL SHC 626 (--- QTS)

Sample Rating Trend Neudo18 Aprilo19 Octo13 Aprilo20 Octo23 Aprilo24



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil

Fluid Condition

The condition of the oil is acceptable for the time in service.

SAMPLE INFORMA	TION	method	limit/base	Clarront	hiotory	history2
	ATION		ilmii/base	current	history1	,
Sample Number		Client Info		WC0932036	WC0864074	WC0458071
Sample Date		Client Info		17 Apr 2024	24 Oct 2023	22 Apr 2020
3-	nths	Client Info		0	0	0
J	nths	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>2	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron p	opm	ASTM D5185m	>20	<1	0	1
Chromium p	opm	ASTM D5185m	>20	0	0	0
Nickel p	opm	ASTM D5185m	>20	0	0	0
Titanium p	opm	ASTM D5185m		0	0	0
Silver p	opm	ASTM D5185m		0	0	0
Aluminum p	opm	ASTM D5185m	>20	0	0	<1
Lead p	opm	ASTM D5185m	>20	0	0	0
Copper	opm	ASTM D5185m	>20	<1	0	<1
Tin p	opm	ASTM D5185m	>20	0	0	0
Antimony p	opm	ASTM D5185m				1
Vanadium p	opm	ASTM D5185m		0	0	0
Cadmium p	opm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron p	opm	ASTM D5185m		0	0	<1
Barium p	opm	ASTM D5185m		0	<1	0
Molybdenum p	opm	ASTM D5185m		0	0	0
Manganese p	opm	ASTM D5185m		<1	0	0
Magnesium p	opm	ASTM D5185m		0	<1	0
Calcium p	opm	ASTM D5185m		2	1	0
	opm	ASTM D5185m		450	428	444
	opm	ASTM D5185m		0	3	2
	opm	ASTM D5185m		75	48	38
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon p	opm	ASTM D5185m	>15	<1	0	0
	opm	ASTM D5185m		0	0	0
	opm	ASTM D5185m	>20	0	0	0
VISUAL		method	limit/base	current	history1	history2
White Metal s	scalar	*Visual	NONE	LIGHT	NONE	NONE
	scalar	*Visual	NONE	NONE	NONE	NONE
	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate s						
			NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE NONE	NONE	NONE
Silt s Debris s	scalar scalar	*Visual *Visual	NONE	NONE	NONE	NONE
Silt s Debris s Sand/Dirt s	scalar	*Visual				

NORML

>2

scalar *Visual

scalar *Visual

*Visual

scalar

NORML

NEG

NEG

NORML

NEG

Odor

Emulsified Water


NORML

0.2%


ed By HAICHAEL VILLASENOR



OIL ANALYSIS REPORT









Certificate 12367

Laboratory

Lab Number : 06160839 Unique Number : 10996262 Test Package : IND 1

Sample No. : WC0932036

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Tested

Received : 25 Apr 2024 : 26 Apr 2024

Diagnosed : 29 Apr 2024 - Don Baldridge

GREELEY, CO US 80631-5909

Contact: ERIC KLINE EKLINE@LEPRINOFOODS.COM

1302 1ST AVE

LEPRINO FOODS-GREELEY

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

F: (970)347-5190 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)