


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# KAESER SX 6 2563455 (S/N 2894)

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

## **DIAGNOSIS**

#### Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil. Elemental level of silicon (Si) above normal.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Aug2022	Apr2024		
SAMPLE INFORM	AATIONI	method	limit/base	ourront.	historyd	hiotom (O
	MATION		iiiiii/base	current	history1	history2
Sample Number		Client Info		KCPA013505	KCP48270	
Sample Date		Client Info		16 Apr 2024	23 Aug 2022	
Machine Age	hrs	Client Info		23513	21579	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		Changed	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	10	29	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	<1	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	36	<u>^</u> 72	
Tin	ppm	ASTM D5185m	>10	<1	<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	2	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m	100	13	0	
Calcium	ppm	ASTM D5185m	0	<1	0	
Phosphorus	ppm	ASTM D5185m	0	35	147	
Zinc	ppm	ASTM D5185m	0	65	117	
Sulfur	ppm	ASTM D5185m	23500	18059	5924	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<u> </u>	9	
Sodium	ppm	ASTM D5185m		3	1	
Potassium	ppm	ASTM D5185m	>20	2	0	
Water	%	ASTM D6304	>0.05	0.006	0.003	
ppm Water	ppm	ASTM D6304	>500	61	28.8	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		209231	30737	
Particles >6µm		ASTM D7647	>1300	<b>59596</b>	<u></u> 6174	
Particles >14µm		ASTM D7647	>80	<b>2774</b>	<u>169</u>	
Particles >21µm		ASTM D7647	>20	<u>▲</u> 529	<b>△</b> 30	
Particles >38μm		ASTM D7647	>4	<u>^</u> 8	2	
Particles >71μm		ASTM D7647	>3	0	1	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>25/23/19</b>	<u>22/20/15</u>	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
A = : = ! N		4 OTM D00 45	4.0	0.417	0.04	

Acid Number (AN)

mg KOH/g ASTM D8045 1.0

0.61

0.417



## **OIL ANALYSIS REPORT**





Certificate 12367

Laboratory Sample No.

: KCPA013505 Lab Number : 06160936 Unique Number : 10996359

Received **Tested** Diagnosed Test Package : IND 2 ( Additional Tests: KF, PrtCount )

: 26 Apr 2024

: 25 Apr 2024

: 29 Apr 2024 - Don Baldridge

US 95324 Contact: J. GUTIERREZ jgutierrez@hilmarcheese.com T:

9001 N LANDER AVE

To discuss this sample report, contact Customer Service at 1-800-237-1369.  $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F:

HILMAR, CA