

# **OIL ANALYSIS REPORT**

Sample Rating Trend

ISO

Machine Id

# 8304726 (S/N 4292)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

## **DIAGNOSIS**

#### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

## Contamination

There is a high amount of particulates present in the oil.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Apr2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA016423		
Sample Date		Client Info		22 Apr 2024		
Machine Age	hrs	Client Info		2345		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Not Changd		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
		ASTM D5185m			Thotory 1	motory
Iron	ppm		>50	<1		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	<1		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m	>50	2		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	90	16		
Molybdenum	ppm	ASTM D5185m	0	0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	100	48		
Calcium	ppm	ASTM D5185m	0	<1		
Phosphorus	ppm	ASTM D5185m	0	1		
Zinc	ppm	ASTM D5185m	0	5		
Sulfur	ppm	ASTM D5185m	23500	22700		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m	720	10		
Potassium	ppm	ASTM D5185m	>20	13		
Water	%	ASTM D6304	>0.05	0.029		
ppm Water	ppm	ASTM D6304	>500	299		
FLUID CLEANLIN		method	limit/base	current	history1	history2
			mini/base			-
Particles >4µm		ASTM D7647	1000	27413		
Particles >6µm		ASTM D7647		<u>^</u> 4642		
Particles >14µm		ASTM D7647	>80	▲ 171		
Particles >21µm		ASTM D7647	>20	<u> </u>		
Particles >38µm		ASTM D7647	>4	1		
Particles >71μm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>22/19/15</u>		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.40		



## **OIL ANALYSIS REPORT**





Certificate 12367

Laboratory Sample No.

Lab Number

: KCPA016423 : 06160945 Unique Number : 10996368

Received **Tested** Diagnosed

: 26 Apr 2024 : 29 Apr 2024 - Don Baldridge

: 25 Apr 2024

Test Package : IND 2 ( Additional Tests: KF, PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369.  $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation. CT NASSAU TICKING LLC

1504 ANTHONY RD BURLINGTON, NC US 27215

Contact: BRIAN ROBERTS brian.g.roberts.82@gmail.com

T:

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) Report Id: CTNBUR [WUSCAR] 06160945 (Generated: 04/29/2024 12:18:55) Rev: 1

Contact/Location: BRIAN ROBERTS - CTNBUR

F: