


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER ESD 300 7824194 (S/N 1479)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Ma	2022	Nov2022 Apr202	4	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA012715	KCP40020	KCP38080
Sample Date		Client Info		19 Apr 2024	21 Nov 2022	08 Mar 2022
Machine Age	hrs	Client Info		18476	9155	4779
Oil Age	hrs	Client Info		6571	1908	1800
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	0	<1
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m	>50	2	8	4
Tin	ppm	ASTM D5185m	>10	0	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m	90	0	1	33
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	<1	2	37
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		0	10	11
Zinc	ppm	ASTM D5185m		4	0	0
Sulfur	ppm	ASTM D5185m		19416	17341	16465
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	2	<1
Sodium	ppm	ASTM D5185m		<1	<1	13
Potassium	ppm	ASTM D5185m	>20	<1	<1	4
Water	%	ASTM D6304	>0.05	0.005	0.005	0.009
ppm Water	ppm	ASTM D6304	>500	59	56.3	94.2
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		4440	38689	
Particles >6µm		ASTM D7647	>1300	<u> </u>	<u>▲</u> 18287	
Particles >14μm		ASTM D7647	>80	<u> </u>	△ 317	
Particles >21µm		ASTM D7647	>20	<u>^</u> 54	<u>47</u>	
Particles >38µm		ASTM D7647	>4	2	1	
Particles >71µm		ASTM D7647	>3	1	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/18/15	<u>22/21/15</u>	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.54	0.50	0.45



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number : 06160960 Unique Number: 10996383

: KCPA012715

Received **Tested** Diagnosed Test Package : IND 2 (Additional Tests: KF, PrtCount)

: 25 Apr 2024 : 26 Apr 2024

: 29 Apr 2024 - Don Baldridge

US 43054 Contact: P. LONGIA plongia@axiumplastics.com T:

9005 SMITHS MILL RD

NEW ALBANY, OH

To discuss this sample report, contact Customer Service at 1-800-237-1369. st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: