

### **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# **KAESER 7471636**

### Component Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

#### DIAGNOSIS

#### Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is a high amount of particulates present in the oil.

#### Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. Viscosity of sample indicates oil is within ISO 32 range, advise investigate. Confirm oil type. The AN level is acceptable for this fluid.

SAMPLE INFORM	<b>IATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		KC06160965	KC124487	KC85314
Sample Date		Client Info		01 Apr 2024	29 Nov 2023	14 Jul 2021
Machine Age	hrs	Client Info		12598	11776	3434
Oil Age	hrs	Client Info		0	0	1565
Oil Changed		Client Info		N/A	N/A	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	2
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m		0	10	8
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES	pp	method	limit/base	current		-
			IIIIIVDase		history1	history2
Boron	ppm	ASTM D5185m	00	0	0	11
Barium	ppm	ASTM D5185m	90	6	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m	00	0	<1	0
Magnesium	ppm	ASTM D5185m	90	<1	2	18
Calcium	ppm	ASTM D5185m	2	<1	<1	0
Phosphorus	ppm	ASTM D5185m		<b>367</b>	1	2
Zinc	ppm	ASTM D5185m		16	0	23
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	1
Sodium	ppm	ASTM D5185m		21	1	14
Potassium	ppm	ASTM D5185m	>20	1	2	8
Water	%	ASTM D6304		0.032	0.029	0.022
ppm Water	ppm	ASTM D6304	>500	326	300	226.7
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		13473		4778
Particles >6µm		ASTM D7647	>1300	<u> </u>		995
Particles >14µm		ASTM D7647	>80	<u> </u>		91
Particles >21µm		ASTM D7647	>20	<u> </u>		23
Particles >38µm		ASTM D7647	>4	1		2
Particles >71µm		ASTM D7647		0		0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>A</b> 21/19/15		17/14
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.16	0.33	0.319

Contact/Location: Service Manager - CLIORL Page 1 of 2


## COMPRESSOR Built for a lifetime.


14k 12


mber of particles (1 ml) 98 88 98 48

21 0

500 40 300








# **OIL ANALYSIS REPORT**

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	🔺 MODER	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
FLUID PROPERT Visc @ 40°C	IES cSt	method ASTM D445	limit/base	current	history1 44.1	history2 44.2
	cSt					
Visc @ 40°C	cSt	ASTM D445	46	31.2	44.1	44.2



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Service Manager - CLIORL Page 2 of 2

F: