

OIL ANALYSIS REPORT

Sample Rating Trend **WATER**

Machine Id

N/A Franklin Precision Industry

Component
Center Fluid

PETRO CANADA HYDREX AW 46 (10 LTR)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We recommend you service the filters on this component. Resample at the next service interval to monitor. (Customer Sample Comment: Could have some type of metal working fluid mixed?)

All component wear rates are normal.

Contamination

Appearance is hazy. There is a light concentration of water present in the fluid. The amount and size of particulates present in the system are acceptable.


Fluid Condition

The AN level is acceptable for this fluid.

		<u>, </u>		Apr2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KFS0005074		
Sample Date		Client Info		24 Apr 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m		0		
Chromium	ppm	ASTM D5185m		0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m		0		
Lead	ppm	ASTM D5185m		0		
Copper	ppm	ASTM D5185m		2		
Tin	ppm	ASTM D5185m		0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	0	0		
Molybdenum	ppm	ASTM D5185m	0	0		
Manganese	ppm	ASTM D5185m	0	0		
Magnesium	ppm	ASTM D5185m	0	0		
Calcium	ppm	ASTM D5185m	50	25		
Phosphorus	ppm	ASTM D5185m	330	293		
Zinc	ppm	ASTM D5185m	430	416		
Sulfur	ppm	ASTM D5185m	760	944		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m		0		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	0		
Water	%	ASTM D6304		△ 0.286		
ppm Water	ppm	ASTM D6304		2860		
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647	>5000	505		
Particles >6µm		ASTM D7647	>1300	275		
Particles >14µm		ASTM D7647	>160	47		
Particles >21µm		ASTM D7647	>40	16		
Particles >38µm		ASTM D7647	>10	2		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>19/17/14	16/15/13		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.70	0.64		



OIL ANALYSIS REPORT





Certificate 12367

Lab Number

Laboratory Sample No.

: KFS0005074

: 06161398 Unique Number: 10996821

Received : 26 Apr 2024 **Tested** : 02 May 2024 Diagnosed : 02 May 2024 - Jonathan Hester

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

KIMBRO OIL COMPANY

2200 CLIFTON AVE NASHVILLE, TN US 37203 Contact: CHRIS HIGGINS

chiggins@kimbrooil.com

T: (270)305-1347