


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER AIRCENTER SX 6 8014269 - WEST ROCK (S/N 2758)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

Appearance is hazy. There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

	Dec2022 Oct2023 Αρτ2024					
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA017130	KCPA004560	KCP52007
Sample Date		Client Info		03 Apr 2024	25 Oct 2023	14 Dec 2022
Machine Age	hrs	Client Info		17068	13815	7388
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Not Changd	N/A	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	<1	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	0	<1	<1
Silver	ppm	ASTM D5185m	>2	0	<1	0
Aluminum	ppm	ASTM D5185m	>10	0	2	2
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m	>50	2	10	8
Tin	ppm	ASTM D5185m	>10	0	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	<1
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	<1	<1
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	90	33	18	16
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		0	4	3
Zinc	ppm	ASTM D5185m		0	7	0
Sulfur	ppm	ASTM D5185m		21352	19397	20512
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	<1
Sodium	ppm	ASTM D5185m		12	3	8
Potassium	ppm	ASTM D5185m	>20	0	2	<1
Water	%	ASTM D6304	>0.05	<u> </u>	0.014	0.011
ppm Water	ppm	ASTM D6304	>500	<u> </u>	149.9	116.4
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		678	10743	5460
Particles >6µm		ASTM D7647	>1300	370	4308	<u>\$\text{2321}\$</u>
Particles >14μm		ASTM D7647	>80	63	▲ 380	<u>4</u> 242
Particles >21µm		ASTM D7647	>20	21	<u></u> 96	<u></u> ▲ 61
Particles >38μm		ASTM D7647	>4	3	3	<u>^</u> 7
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/16/13	2 1/19/16	2 0/18/15
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.36	0.24	0.28



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number : 06161439 Unique Number : 10996862

: KCPA017130

Received Tested Diagnosed Test Package : IND 2 (Additional Tests: KF, PrtCount)

: 26 Apr 2024 : 02 May 2024

: 02 May 2024 - Jonathan Hester

US 22408 Contact: Warranty Department warranty.us@kaeser.com T: (540)898-5500

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (540)898-5520 Contact/Location: Warranty Department - KAEFRE

511 SIGMA DRIVE

FREDERICKSBURG, VA