




# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**BAGLINE**  
 Machine Id  
**KETTLE 2 - 11531818**  
 Component  
**Refrigeration Compressor**  
 Fluid  
**PETRO CANADA PURITY FG EP GEAR OIL 220 (1 GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

Insufficient sample was received to conduct all the routine laboratory tests. There is a high amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The condition of the oil is acceptable for the time in service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>USP0006695</b>	USP0004463	USP250214
Sample Date	Client Info		<b>25 Apr 2024</b>	17 Dec 2023	05 Jul 2023
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >8	<b>0</b>	<1	2
Chromium	ppm	ASTM D5185m >2	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >3	<b>0</b>	0	<1
Lead	ppm	ASTM D5185m >2	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >8	<b>17</b>	14	17
Tin	ppm	ASTM D5185m >4	<b>1</b>	<1	2
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	<1
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>4</b>	2	2
Barium	ppm	ASTM D5185m	<b>0</b>	0	<1
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	0	0
Magnesium	ppm	ASTM D5185m	<b>0</b>	0	2
Calcium	ppm	ASTM D5185m	<b>0</b>	0	11
Phosphorus	ppm	ASTM D5185m	<b>548</b>	566	596
Zinc	ppm	ASTM D5185m	<b>0</b>	0	<1
Sulfur	ppm	ASTM D5185m	<b>531</b>	461	706

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<b>6</b>	8	6
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Potassium	ppm	ASTM D5185m >20	<b>0</b>	0	1
Water	%	ASTM D6304 >0.01	<b>0.003</b>	0.002	0.004
ppm Water	ppm	ASTM D6304 >100	<b>33</b>	24	41.6

## FLUID CLEANLINESS






	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	<b>▲ 55352</b>	▲ 49672	▲ 54805
Particles >6µm	ASTM D7647	>2500	<b>▲ 6362</b>	▲ 6433	▲ 6017
Particles >14µm	ASTM D7647	>640	<b>151</b>	52	49
Particles >21µm	ASTM D7647	>160	<b>31</b>	12	10
Particles >38µm	ASTM D7647	>40	<b>1</b>	1	2
Particles >71µm	ASTM D7647	>10	<b>0</b>	1	1
Oil Cleanliness	ISO 4406 (c)	>20/18/16	<b>▲ 23/20/14</b>	▲ 23/20/13	▲ 23/20/13

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974 0.51	<b>---</b>	0.55	0.59




# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	205.8	196	187

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : USP0006695  
**Lab Number** : 06161493  
**Unique Number** : 10996916  
**Test Package** : IND 2  
**Received** : 26 Apr 2024  
**Tested** : 30 Apr 2024  
**Diagnosed** : 30 Apr 2024 - Jonathan Hester

**KraftHeinz - Cedar Rapids - Plant 8370**  
 4601 C ST SW  
 CEDAR RAPIDS, IA  
 US 52404  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)