




# OIL ANALYSIS REPORT



Machine Id  
**Grand Blanc CAT 4 GBLM04BE**  
 Component  
**Biogas Engine**  
 Fluid  
**CHEVRON HDAX 9500 GAS ENGINE OIL 40 (--- GAL)**

Sample Rating Trend



**DIRT**



## DIAGNOSIS

### ▲ Recommendation

Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition. ( Customer Sample Comment: 950hr End of Cycle Oil sample )

### Wear

All component wear rates are normal.

### ▲ Contamination

Elemental level of silicon (Si) above normal.

### ▲ Fluid Condition

The BN level is low. The AN level is acceptable for this fluid.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0905701</b>	WC0905672	WC0905753
Sample Date	Client Info		<b>24 Apr 2024</b>	18 Apr 2024	10 Apr 2024
Machine Age	hrs	Client Info	<b>69243</b>	69082	68870
Oil Age	hrs	Client Info	<b>950</b>	795	0
Oil Changed	Client Info		<b>Changed</b>	Not Changd	N/A
Sample Status			<b>SEVERE</b>	SEVERE	ABNORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<b>&lt;1.0</b>	<1.0	<1.0
Water	WC Method	>.11	<b>NEG</b>	NEG	NEG
Glycol	WC Method		<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >15	<b>8</b>	6	6
Chromium	ppm	ASTM D5185m >4	<b>&lt;1</b>	<1	<1
Nickel	ppm	ASTM D5185m	<b>0</b>	0	1
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >6	<b>3</b>	2	2
Lead	ppm	ASTM D5185m >9	<b>3</b>	2	4
Copper	ppm	ASTM D5185m >6	<b>2</b>	3	2
Tin	ppm	ASTM D5185m >4	<b>2</b>	3	3
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	<1
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	<1

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>2</b>	4	3
Barium	ppm	ASTM D5185m	<b>0</b>	1	0
Molybdenum	ppm	ASTM D5185m	<b>3</b>	2	3
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	1	1
Magnesium	ppm	ASTM D5185m	<b>12</b>	14	10
Calcium	ppm	ASTM D5185m	<b>1965</b>	1984	1786
Phosphorus	ppm	ASTM D5185m	<b>278</b>	286	288
Zinc	ppm	ASTM D5185m	<b>347</b>	360	335
Sulfur	ppm	ASTM D5185m	<b>3705</b>	3698	3317

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >181	<b>▲ 205</b>	▲ 187	153
Sodium	ppm	ASTM D5185m >21	<b>2</b>	2	0
Potassium	ppm	ASTM D5185m >20	<b>0</b>	0	3

## INFRA-RED






	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	<b>0.1</b>	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	<b>5.9</b>	5.8	5.7
Sulfation	Abs/.1mm	*ASTM D7415	<b>24.9</b>	24.1	22.9

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	<b>16.0</b>	15.1	14.3
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	<b>2.26</b>	2.18	▲ 2.04
Base Number (BN)	mg KOH/g	ASTM D2896 5.4	<b>▲ 1.83</b>	▲ 1.97	2.22











# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	LIGHT	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.11	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.4	13.7	13.6

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0905701  
**Lab Number** : 06161680  
**Unique Number** : 10997103  
**Test Package** : MOB 2  
**Received** : 26 Apr 2024  
**Tested** : 29 Apr 2024  
**Diagnosed** : 29 Apr 2024 - Sean Felton

**EDL NA Recips-Grand Blanc**  
 Grand Blanc Powerstation, 2361 West Grand Blanc Road  
 Grand Blanc, MI  
 US 48439  
 Contact: Tony Saint Marie  
 tony.saintmarie@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)