


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

7618823 (S/N 1004)Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Dec2021	Dec2022	Mar2023 Feb 2024	May2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA013338	KCP47439D	KCP54059
Sample Date		Client Info		01 May 2024	01 Feb 2024	30 Mar 2023
Machine Age	hrs	Client Info		23032	3180	17018
Oil Age	hrs	Client Info		2753	3180	2653
Oil Changed		Client Info		Not Changd	Changed	Not Changd
Sample Status				ATTENTION	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	21
Chromium	ppm	ASTM D5185m	>10	0	<1	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	0	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	3	7	9
Lead	ppm	ASTM D5185m	>10	0	1	0
Copper	ppm	ASTM D5185m	>50	5	5	8
Tin	ppm	ASTM D5185m	>10	<1	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	0	39	0
Molybdenum	ppm	ASTM D5185m	0	0	<1	0
Manganese	ppm	ASTM D5185m		<1	1	<1
Magnesium	ppm	ASTM D5185m	100	14	68	2
Calcium	ppm	ASTM D5185m	0	2	5	<1
Phosphorus	ppm	ASTM D5185m	0	4	39	46
Zinc	ppm	ASTM D5185m	0	135	40	121
Sulfur	ppm	ASTM D5185m	23500	21533	20920	19923
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	<1
Sodium	ppm	ASTM D5185m		10	4	<1
Potassium	ppm	ASTM D5185m	>20	7	20	<1
Water	%	ASTM D6304	>0.05	0.011	0.020	△ 0.322
ppm Water	ppm	ASTM D6304	>500	117	200	▲ 3220
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		7541		
Particles >6µm		ASTM D7647	>1300	<u> </u>		
Particles >14μm		ASTM D7647	>80	111		
Particles >21µm		ASTM D7647	>20	32		
Particles >38μm		ASTM D7647	>4	3		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	20/18/14		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.44	0.59	0.44



OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number

: 06174618

: KCPA013338 Unique Number : 11020671

Received : 09 May 2024 **Tested** Diagnosed

: 10 May 2024

: 13 May 2024 - Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

2221 PINE VIEW WAY PETALUMA, CA US 94954 Contact: M. SHEEHAN

msheehan@parmatech.com

T:

F: