


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# KAESER 4238047 (S/N 1081)

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

### Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

## Contamination

There is a moderate amount of particulates present in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jun2021 Jun2023 Apr2024				
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA013344	KCPA003898	KCP33947
Sample Date		Client Info		29 Apr 2024	07 Jun 2023	16 Jun 2021
Machine Age	hrs	Client Info		73084	65260	48463
Oil Age	hrs	Client Info		0	0	3639
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				ATTENTION	NORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	<1	0
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m	>50	2	15	2
Tin	ppm	ASTM D5185m	>10	<1	0	<1
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	17
Barium	ppm	ASTM D5185m	90	0	0	16
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	100	0	<1	25
Calcium	ppm	ASTM D5185m	0	0	0	22
Phosphorus	ppm	ASTM D5185m	0	0	27	12
Zinc	ppm	ASTM D5185m	0	0	10	10
Sulfur	ppm	ASTM D5185m	23500	20812	17613	18167
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	1	1
Sodium	ppm	ASTM D5185m		1	<1	7
Potassium	ppm	ASTM D5185m	>20	1	0	2
Water	%	ASTM D6304	>0.05	0.002	0.006	0.010
ppm Water	ppm	ASTM D6304	>500	25	66.6	106.3
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		5007	1717	8821
Particles >6µm		ASTM D7647	>1300	1300	501	0 2011
Particles >14μm		ASTM D7647	>80	<b>124</b>	48	124
Particles >21µm		ASTM D7647	>20	<b>43</b>	17	<b>3</b> 1
Particles >38μm		ASTM D7647	>4	3	1	0
Particles >71µm		ASTM D7647	>3	1	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>20/17/14</b>	18/16/13	18/14
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



# **OIL ANALYSIS REPORT**







Certificate 12367

Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KCPA013344 Lab Number : 06174624

Unique Number : 11020677

Received : 09 May 2024 **Tested** Diagnosed

: 10 May 2024

: 13 May 2024 - Don Baldridge

Test Package : IND 2 ( Additional Tests: KF, PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369.  $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: JOHN CROWLEY - UHARAN

US 95670

T:

F:

**U-HAUL REPAIR** 

11351 PYRITES WAY

RANCHO CORDOVA, CA

Contact: JOHN CROWLEY

john\_crowley@uhaul.com