

## **OIL ANALYSIS REPORT**

Machine Id

## KAESER CSD 75 5080247 (S/N 1056)

Component Compressor

Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

#### DIAGNOSIS

#### Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear


All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



		method	iiiiii/base	current	HIStOLA	Thistory 2
Sample Number		Client Info		KCPA015302	KCPA000276	KCP51583
Sample Date		Client Info		26 Apr 2024	01 Mar 2023	22 Jul 2022
Machine Age	hrs	Client Info		44182	39591	35675
Oil Age	hrs	Client Info		3706	0	0
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	nnm	ASTM D5185m		0	0	0
Chromium	ppm	ASTM D5185m		0	<1	0
Nickel	ppm	ASTM D5185m		0	<1	0
Titanium	ppm			0	<1	0
Silver	ppm	ASTM D5185m			<1	0
	ppm	ASTM D5185m		0	<1	1
Aluminum	ppm	ASTM D5185m				
Lead	ppm	ASTM D5185m		0 11	0	<1
Copper	ppm	ASTM D5185m				11
Tin	ppm	ASTM D5185m	>10	<1	0	<1
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	2	55	36
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	1	0
Magnesium	ppm	ASTM D5185m	100	33	88	63
Calcium	ppm	ASTM D5185m	0	0	2	2
Phosphorus	ppm	ASTM D5185m	0	0	1	5
Zinc	ppm	ASTM D5185m	0	20	1	8
Sulfur	ppm	ASTM D5185m	23500	23561	23550	25310
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	1	3
Sodium	ppm	ASTM D5185m		12	38	34
Potassium	ppm	ASTM D5185m	>20	4	11	13
Water	%	ASTM D6304	>0.05	0.016	0.014	0.029
ppm Water	ppm	ASTM D6304	>500	168	147.1	293.4
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		17711		
Particles >6µm		ASTM D7647	>1300	<u> </u>		
Particles >14µm		ASTM D7647	>80	<b>A</b> 397		
Particles >21µm		ASTM D7647	>20	<u> </u>		
Particles >38µm		ASTM D7647	>4	3		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>A</b> 21/20/16		
FLUID DEGRAD	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.45	0.42	0.49
:14:40) Rev: 1	iiiy NO⊓/ÿ	AG HVI D0043		ct/Location: SEI		

Report Id: AMABAL [WUSCAR] 06174651 (Generated: 05/13/2024 14:14:40) Rev: 1

Contact/Location: SERVICE MANAGER ? - AMABAL



## **OIL ANALYSIS REPORT**

scalar

scalar

scalar

scalar

scalar

scalar

scalar

scalar

scalar

cSt

method

\*Visual

\*Visual

\*Visual

\*Visual

\*Visual

\*Visual

\*Visual

\*Visual

\*Visual

method

ASTM D445

method

scalar \*Visual

limit/base

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

limit/base

limit/base

>0.05

45

current

NONE

NONE

NONE

NONE

LIGHT

NONE

NORML

NORML

curren

current

NEG

NEG

52.8

VISUAL

White Metal

Yellow Metal

Precipitate

Silt

Debris

Odor

Sand/Dirt

Appearance


Free Water


Visc @ 40°C


**Emulsified Water** 


FLUID PROPERTIES


SAMPLE IMAGES












# av17/18 Mar28/1





\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: AMABAL [WUSCAR] 06174651 (Generated: 05/13/2024 14:14:40) Rev: 1

Contact/Location: SERVICE MANAGER ? - AMABAL

Page 2 of 2

T:

F:

history1

NONE

NONE

NONE

NONE

MODER

NONE

NORML

NORML

history

history1

NEG

NEG

51.2

history2

NONE

NONE

NONE

NONE

MODER

NONE

NORML

NORML

history2

history2

NEG

NEG

▲ 54.95

Bottom

Color

