

FUEL REPORT

Area UTILITIES **FUEL STATION 2 - COURTYARD**

Tank Diesel Fuel

Fluid No.2 DIESEL FUEL (ULTRALOW SULPHUR) (2000 GAL)

Recommendation

No corrective action is recommended at this time.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

The water content is negligible. There is no indication of any contamination in the fuel.

Fuel Condition

The condition of the fuel is acceptable for the time in service.

NORMAL




Sample Rating Trend


SAMPLE INFORM	1ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RP0039291	RP0042672	RP0038042
Sample Date		Client Info		08 May 2024	26 Mar 2024	29 Feb 2024
Machine Age	mls	Client Info		0	0	0
Sample Status				NORMAL	NORMAL	NORMAL
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	3.0	2.79	2.77	2.89
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0	0	<1
Sodium	ppm	ASTM D5185m	<0.1	<1	2	<1
Potassium	ppm	ASTM D5185m	<0.1	0	0	0
Water	%	ASTM D6304	<0.05	0.002	0.002	0.003
ppm Water	ppm	ASTM D6304	<500	24	20	28
HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	0	0	0
Nickel	ppm	ASTM D5185m	<0.1	0	0	0
Lead	ppm	ASTM D5185m	<0.1	0	0	0
Vanadium	ppm	ASTM D5185m	<0.1	0	<1	0
Iron	ppm	ASTM D5185m	<0.1	0	0	0
Calcium	ppm	ASTM D5185m	<0.1	0	0	0
Magnesium	ppm	ASTM D5185m	<0.1	0	0	0
Phosphorus	ppm	ASTM D5185m	<0.1	0	0	0
Zinc	ppm	ASTM D5185m	<0.1	0	0	0
SAMPLE IMAGES	\$	method	limit/base	current	history1	history2
Color						
Bottom						



FUEL REPORT



Pensky-Martens Flash Point (°C)													
mper	8	•											
	6												
	4												
	ပ 2												
	, atrice												
	emper												
	₽ -2												
	-4												
	-6												
	-8												
	-10												
		Aug2/21	Vov24/21	Apr6/22	Aug2/22	Jan4/23	May2/23	ep27/23	an 29/24				



Submitted By: DALE ROBINSON Page 2 of 2

HWY 43 N

US 36513

F: x:

CALVERT, AL