




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
UTILITIES
 Machine Id
FUEL STATION 3 UNITED RENTALS
 Component
Diesel Exhaust Fluid (DEF)
 Fluid
DEF (Diesel Exhaust Fluid) (275 GAL)

DIAGNOSIS

Recommendation

Fluid meets ISO 22241-2 requirements and is suitable for use.

Contamination

Appearance is acceptable. There is no indication of any contamination in the diesel exhaust fluid (def).

Fluid Condition

Urea content is normal.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			RP0042517	RP0042671	RP0038043
Sample Date	Client Info			08 May 2024	26 Mar 2024	29 Feb 2024
Machine Age	mls	Client Info		0	0	0
Oil Age	mls	Client Info		0	0	0
Oil Changed	Client Info			N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL

CONTAMINANTS		method	limit/base	current	history1	history2
Hydrocarbon	scalar	*In-House		NONE	NONE	NONE

FLUID PROPERTIES		method	limit/base	current	history1	history2
Urea Content	%	ISO 22241	<31.8	32.7	32.7	32.7
Density @ 20°C	g/cm3	ISO 22241	>1.0930	1.0895	1.0887	1.0888
Refracting Index		ISO 22241	<1.3814	1.3827	1.3827	1.3828
Appearance	scalar	*Visual		Clear & Bright	Clear & Bright	Clear & Bright

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------


Color





Bottom



OIL ANALYSIS REPORT



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : RP0042517
Lab Number : 06175053
Unique Number : 11021106
Test Package : DEF 1 (Additional Tests: ICP, KF, KV40, SCREEN, TAN Man)

Received : 09 May 2024
Tested : 17 May 2024
Diagnosed : 17 May 2024 - Angela Borella

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

OUTOKUMPU STAINLESS USA
 HWY 43 N
 CALVERT, AL
 US 36513
 Contact: MARIO JOHNSON
 Mario.johnson@outokumpu.com
 T: (251)321-4105
 F: x: