


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

5752832 (S/N 1122) Component Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Apr2022 Jan2024 May2024				
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA013388	KCPA006531	KCP44904
Sample Date		Client Info		06 May 2024	12 Jan 2024	01 Apr 2022
Machine Age	hrs	Client Info		39320	36763	24582
Oil Age	hrs	Client Info		0	0	317
Oil Changed		Client Info		Not Changd	N/A	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1	0	1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	10	3	2
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	4	3	8
Tin	ppm	ASTM D5185m	>10	<1	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		4	0	18
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m		5	<1	40
Calcium	ppm	ASTM D5185m		<1	<1	0
Phosphorus	ppm	ASTM D5185m	500	392	110	8
Zinc	ppm	ASTM D5185m		234	68	21
Sulfur	ppm	ASTM D5185m		3471	1186	16737
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	<1
Sodium	ppm	ASTM D5185m		<1	0	10
Potassium	ppm	ASTM D5185m	>20	<1	0	6
Water	%	ASTM D6304	>0.05	0.004	0.003	0.014
ppm Water	ppm	ASTM D6304	>500	47	34	141.5
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		15610	9217	16088
Particles >6μm		ASTM D7647	>1300	<u>^</u> 2932	<u>^</u> 2910	<u>4480</u>
Particles >14μm		ASTM D7647	>80	<u>148</u>	434	△ 390
Particles >21µm		ASTM D7647	>20	<u>41</u>	<u>108</u>	<u>128</u>
Particles >38µm		ASTM D7647	>4	3	1	<u> 11</u>
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>21/19/14</u>	<u>^</u> 20/19/16	<u>19/16</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	ma KOH/a	ASTM D8045	1.5	1 13	0.35	0.40

Acid Number (AN)

mg KOH/g ASTM D8045 1.5

0.35

1.13

0.40



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

: KCPA013388 : 06175492

Lab Number Unique Number : 11021545

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

Received

Diagnosed

Tested

: 10 May 2024

: 14 May 2024

: 14 May 2024 - Angela Borella

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

COAST PACKING CO

3275 E VERNON AVE VERNON, CA US 90058

Contact: Service Manager

T:

F: