




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area

MELT SHOP - HYDRAULIC

Machine Id

MELT SHOP EAF-DE-SLAG HYDRAULIC UNIT (S/N 15-2000-0770)

Component

Tank Hydraulic System

Fluid

FIRE-RESISTANT FLUID ISO 46 (200 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The pH level of this fluid is within the acceptable limits at 9.0. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	RP0042068	RP0042718	RP0042699
Sample Date	Client Info	09 May 2024	28 Mar 2024	12 Mar 2024
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		NORMAL	NORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2
Iron ppm	ASTM D5185m >20	0	2	▲ 45
Chromium ppm	ASTM D5185m >20	0	1	<1
Nickel ppm	ASTM D5185m >20	0	1	<1
Titanium ppm	ASTM D5185m	0	<1	0
Silver ppm	ASTM D5185m	0	0	0
Aluminum ppm	ASTM D5185m >20	0	11	11
Lead ppm	ASTM D5185m >20	0	0	0
Copper ppm	ASTM D5185m >20	<1	<1	<1
Tin ppm	ASTM D5185m >20	0	1	<1
Vanadium ppm	ASTM D5185m	0	1	1
Cadmium ppm	ASTM D5185m	0	<1	<1

ADDITIVES

method	limit/base	current	history1	history2
Boron ppm	ASTM D5185m 5	0	3	2
Barium ppm	ASTM D5185m 5	0	0	0
Molybdenum ppm	ASTM D5185m 5	0	<1	0
Manganese ppm	ASTM D5185m	0	<1	0
Magnesium ppm	ASTM D5185m 5	<1	<1	1
Calcium ppm	ASTM D5185m 50	0	6	7
Phosphorus ppm	ASTM D5185m 175	2	5	4
Zinc ppm	ASTM D5185m 62	14	2	46






CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm	ASTM D5185m >15	<1	3	3
Sodium ppm	ASTM D5185m	0	45	36
Potassium ppm	ASTM D5185m >20	0	6	7
Water %	ASTM D6304 >55	38.7	39.1	35.9
ppm Water	ASTM D6304 >55000	387000	391000	359000

FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	940	1331	835
Particles >6µm	ASTM D7647 >1300	512	725	455
Particles >14µm	ASTM D7647 >160	87	123	77
Particles >21µm	ASTM D7647 >40	29	42	26
Particles >38µm	ASTM D7647 >10	5	6	4
Particles >71µm	ASTM D7647 >3	0	1	0
Oil Cleanliness	ISO 4406 (c) >19/17/14	17/16/14	18/17/14	17/16/13


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>55	0.2%	0.2%
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
pH	Scale 0-14	ASTM D1287	9.00	9.00	11.0
Visc @ 40°C	cSt	ASTM D445	46	48.0	53.0

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : RP0042068 **Received** : 10 May 2024
Lab Number : 06175584 **Tested** : 16 May 2024
Unique Number : 11021637 **Diagnosed** : 16 May 2024 - Jonathan Hester
Test Package : IND 2 (Additional Tests: pH, ReserveAlk)

OUTOKUMPU STAINLESS USA
 HWY 43 N
 CALVERT, AL 36513
 Contact: MARIO JOHNSON
 Mario.johnson@outokumpu.com
 T: (251)321-4105
 F: x:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)