




# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area

**MELT SHOP - HYDRAULIC**

Machine Id

**MELT SHOP LSG LADLE SLIDE GATE (S/N 15-4000-0770)**

Component

**Hydraulic System**

Fluid

**FIRE-RESISTANT FLUID ISO 46 (66 GAL)**

## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The pH level of this fluid is within the acceptable limits at 9.0. The condition of the oil is acceptable for the time in service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>RP0042702</b>	RP0042695	RP0042648
Sample Date	Client Info	<b>09 May 2024</b>	28 Mar 2024	05 Mar 2024
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	NORMAL	NORMAL

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >20	<b>0</b>	3	4
Chromium	ppm	ASTM D5185m >20	<b>0</b>	1	<1
Nickel	ppm	ASTM D5185m >20	<b>0</b>	1	<1
Titanium	ppm	ASTM D5185m	<b>0</b>	<1	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >20	<b>0</b>	12	11
Lead	ppm	ASTM D5185m >20	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >20	<b>&lt;1</b>	<1	<1
Tin	ppm	ASTM D5185m >20	<b>0</b>	1	<1
Vanadium	ppm	ASTM D5185m	<b>0</b>	1	1
Cadmium	ppm	ASTM D5185m	<b>0</b>	<1	<1

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 5	<b>0</b>	3	3
Barium	ppm	ASTM D5185m 5	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m 5	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	<1	0
Magnesium	ppm	ASTM D5185m 5	<b>&lt;1</b>	<1	<1
Calcium	ppm	ASTM D5185m 50	<b>0</b>	6	5
Phosphorus	ppm	ASTM D5185m 175	<b>0</b>	7	3
Zinc	ppm	ASTM D5185m 62	<b>12</b>	3	1

## CONTAMINANTS


method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >15	<b>&lt;1</b>	3	3
Sodium	ppm	ASTM D5185m	<b>0</b>	44	47
Potassium	ppm	ASTM D5185m >20	<b>&lt;1</b>	6	7
Water	%	ASTM D6304 >55	<b>38.6</b>	38.3	41.1
ppm Water	ppm	ASTM D6304 >55000	<b>386000</b>	383000	411000

## FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	<b>▲ 15416</b>	757	974
Particles >6µm	ASTM D7647 >1300	<b>▲ 8398</b>	412	531
Particles >14µm	ASTM D7647 >160	<b>▲ 1429</b>	70	90
Particles >21µm	ASTM D7647 >40	<b>▲ 481</b>	24	30
Particles >38µm	ASTM D7647 >10	<b>▲ 74</b>	4	5
Particles >71µm	ASTM D7647 >3	<b>▲ 8</b>	0	0
Oil Cleanliness	ISO 4406 (c) >19/17/14	<b>▲ 21/20/18</b>	17/16/13	17/16/14

# OIL ANALYSIS REPORT


## Particle Trend




## Water (KF)




## Reserve Alkalinity



## Viscosity @ 40°C




## Reserve Alkalinity



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>55	0.2%	0.2%
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
pH	Scale 0-14 ASTM D1287		9.00	9.00	10.0
Visc @ 40°C	cSt ASTM D445	46	44.4	47.5	44.6

## SAMPLE IMAGES




## GRAPHS


### Ferrous Alloys




### Non-ferrous Metals




### Viscosity @ 40°C



### Particle Count



### Acid Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : RP0042702 **Received** : 10 May 2024  
**Lab Number** : 06175586 **Tested** : 16 May 2024  
**Unique Number** : 11021639 **Diagnosed** : 16 May 2024 - Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: pH, ReserveAlk )

**OUTOKUMPU STAINLESS USA**  
 HWY 43 N  
 CALVERT, AL 36513  
 Contact: MARIO JOHNSON  
 Mario.johnson@outokumpu.com  
 T: (251)321-4105  
 F: x:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)