


# **OIL ANALYSIS REPORT**

### Sample Rating Trend



**NORMAL** 



Machine Id

# **GENERAL ELECTRIC EM1001-L - BOOSTER 1**

**Lower Bearing** 

**ROYAL PURPLE SYNFILM 32 (5 GAL)** 

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RP0032638	RP0020495	RP0020496
Sample Date		Client Info		17 Apr 2024	12 Apr 2022	12 Apr 2022
Machine Age	hrs	Client Info		22465	14158	14158
Oil Age	hrs	Client Info		0	2657	2657
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				NORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	<1	0	<1
Chromium	ppm	ASTM D5185m	>20	0	0	0
Nickel	ppm	ASTM D5185m	>20	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	<1	<1
Aluminum	ppm	ASTM D5185m	>20	0	<1	<1
Lead	ppm	ASTM D5185m	>20	7	1	<u>^</u> 22
Copper	ppm	ASTM D5185m	>20	<1	<1	2
Tin	ppm	ASTM D5185m	>20	0	<1	<1
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	<1	<1
Barium	ppm	ASTM D5185m		<1	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	58	89	76
Calcium	ppm	ASTM D5185m		<1	2	1
Phosphorus	ppm	ASTM D5185m		0	2	5
Zinc	ppm	ASTM D5185m		8	0	0
CONTAMINANTS method			limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	<1	<1
Sodium	ppm	ASTM D5185m		2	<1	<1
Potassium	ppm	ASTM D5185m	>20	0	0	0
Water	%	ASTM D6304	>2	0.015	0.024	0.023
ppm Water	ppm	ASTM D6304		156	249.4	237.2
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

0.42

Acid Number (AN)


mg KOH/g ASTM D8045


0.39


0.41



# **OIL ANALYSIS REPORT**







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	▲ MODER	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPER	IIES	method	ilmit/base	current	nistory i	nistory2
Visc @ 40°C	cSt	ASTM D445	32	31.3	31.8	30.1

-c	 MACE	$\circ$
SAMP	 VIAUTE	$\mathbf{a}$


Color


**Bottom** 





















Certificate 12367

Laboratory Sample No.

: RP0032638 Lab Number : 06175588 Unique Number : 11021641 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 10 May 2024

**Tested** : 13 May 2024 Diagnosed

: 13 May 2024 - Doug Bogart

To discuss this sample report, contact Customer Service at 1-800-237-1369.

US 80642 Contact: JASON LEFTWICH jason.leftwich@magellanlp.com T:

**SADDLEHORN PIPELINE** 

23634 COUNTY RD 30

HUDSON, CO

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: SADHUD [WUSCAR] 06175588 (Generated: 05/13/2024 14:20:52) Rev: 1

Contact/Location: JASON LEFTWICH - SADHUD

F: