


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

GENERAL ELECTRIC EM1002-U - BOOSTER 2

Upper Bearing

ROYAL PURPLE SYNFILM 32 (15 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The water content is negligible. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RP0032637	RP0020494	RP195766
Sample Date		Client Info		17 Apr 2024	12 Apr 2022	19 Apr 2019
Machine Age	hrs	Client Info		15932	10224	2445
Oil Age	hrs	Client Info		0	3810	2400
Oil Changed	0	Client Info		Not Changd	Not Changd	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	0	0	<1
Chromium	ppm	ASTM D5185m	>20	0	0	0
Nickel	ppm	ASTM D5185m	>20	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	<1	0
Aluminum	ppm	ASTM D5185m	>20	0	<1	<1
Lead	ppm	ASTM D5185m	>20	0	<1	<1
Copper	ppm	ASTM D5185m	>20	0	<1	0
Tin	ppm	ASTM D5185m	>20	0	<1	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	<1	<1
Barium	ppm	ASTM D5185m		<1	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	90	77	82	99
Calcium	ppm	ASTM D5185m		0	2	2
Phosphorus	ppm	ASTM D5185m		0	3	<1
Zinc	ppm	ASTM D5185m		7	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	<1	<1
Sodium	ppm	ASTM D5185m		2	<1	<1
Potassium	ppm	ASTM D5185m	>20	0	0	<1
Water	%	ASTM D6304	>2	0.026	0.019	0.019
ppm Water	ppm	ASTM D6304		262	196.2	190
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

0.35

Acid Number (AN)


mg KOH/g ASTM D8045

0.38


0.296



OIL ANALYSIS REPORT



120	Water (K	F)		
120	Course			
Water (ppm)	0			
× 40	0 -			
20	Abnormal			
) L	5	2	4
	Apr30/18	Apr19/19	Apr12/22	Apr17/24
	A	4	⋖	A



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

I LOID I NOI LIN	TILO	memou			HISTOLAL	HISTOLYZ
Visc @ 40°C	cSt	ASTM D445	32	32.1	32.0	31.4

Color


SAMPLE IMAGES










	D	11	













Laboratory Sample No.

: RP0032637 Lab Number : 06175594 Unique Number : 11021647

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 10 May 2024 **Tested** : 18 May 2024

Diagnosed : 18 May 2024 - Jonathan Hester

Test Package : IND 2 Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

SADDLEHORN PIPELINE

23634 COUNTY RD 30 HUDSON, CO

US 80642 Contact: JASON LEFTWICH

jason.leftwich@magellanlp.com T:

F: